



CITY OF SAINT PAUL
OFFICE OF THE CITY COUNCIL
310 CITY HALL
15 WEST KELLOGG BOULEVARD
SAINT PAUL, MN 55102-1615
EMAIL: legislativehearings@ci.stpaul.mn.us
PHONE: (651) 266-8560 FAX: (651) 266-8574

December 15, 2010

Capital Siding, Windows & Construction
Jeff Moore
9673 Wynstone Drive
Woodbury, MN 55125

Re: Appeal of Window Permit for property at 1485 Holton Street
File No. ALH 10-454

Dear Mr. Moore:

This is to confirm that on December 1, 2010 Marcia Moermond, the Legislative Hearing Officer, reviewed the above-referenced appeal and recommended granting a 5.1-inch variance on the openable height of one double hung replacement egress bedroom window which measured at 18.9 inches high by 23.4 inches wide.

If you have any further questions, you may contact me at 651-266-8563.

Sincerely,

Mai Vang
Legislative Hearing Coordinator

c: Fire Supervisors (email)
Pat Fish (email)
Jim Bloom (email)
Ryan Rehn (email)
Stephen Ubl (email)
File