



## CITY OF SAINT PAUL

OFFICE OF THE CITY COUNCIL

310 CITY HALL

15 WEST KELLOGG BOULEVARD

SAINT PAUL, MN 55102-1615

EMAIL: [legislativehearings@ci.stpaul.mn.us](mailto:legislativehearings@ci.stpaul.mn.us)

PHONE: (651) 266-8560 FAX: (651) 266-8574

November 21, 2011

Penny  
Installation Masters, Inc.  
o/b/o Tony & Katy Harms  
Installation Masters Inc  
359 Wyldwood Ln  
Spring Lake Park MN 55432-0000

VIA EMAIL: [penny@installationmastersinc.com](mailto:penny@installationmastersinc.com)

Re: Appeal for property at 1013 Grotto Street North

Dear Penny:

This is to confirm that Marcia Moermond, Legislative Hearing Officer, reviewed the above-referenced matter and recommended that the City Council grant a 3-inch variance on the openable width of three replacement egress bedroom windows measuring 17 inches wide by 36 and 28 inches high.

The City Council Public Hearing is scheduled for Wednesday, December 21, 2011 at 5:30 p.m. in Room 300 Council Chambers. You don't need to attend this hearing since the appeal has been granted.

If you have any further questions, you may contact me at 651-266-8563.

Sincerely,

/s/

Mai Vang  
Legislative Hearing Coordinator

cc: Fire Supervisors (email)  
Jim Bloom (email)  
Stephen Ubl (email)  
Virgil Thomas (email)