



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

November 8, 2011

JAYANT V SARAPH
PO BOX 14885
MINNEAPOLIS MN 55414-0885

RE: RE-INSPECTION FIRE CERTIFICATE OF OCCUPANCY WITH DEFICIENCIES
601 CLIFFORD ST

Ref. # 107712

Dear Property Representative:

Your building was re-inspected for the Fire Certificate of Occupancy on November 8, 2011. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected immediately. **A reinspection will be made on or after December 15, 2011.**

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional reinspection fees.

DEFICIENCY LIST

1. SBC 3405.1, SBC 110.2 - The occupancy group or use division of this building has been changed from that previously approved. Discontinue the unapproved occupancy or use, or contact the Building Official at 651-266-9071 for a code analysis and to comply with requirements for approved occupancy. - *Building is approved as R-3 two dwelling units and is arranged as R-2 triplex with three separate dwelling units. Basement unit was vacant at time of inspection.*
2. SPLC 62.101 - Use of this property does not conform to zoning ordinance. Discontinue unapproved use or call DSI Zoning at (651) 266-8989 to convert to legal use. Discontinue: - *Building is approved as R-3 two dwelling units and is arranged as R-2 triplex with three separate dwelling units. Basement unit was vacant at time of inspection.*

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

An Equal Opportunity Employer

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at mitchell.imbertson@ci.stpaul.mn.us or call me at 651-266-8986 between 7:30 a.m - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Mitchell Imbertson
Fire Inspection
Ref. # 107712