



CITY OF SAINT PAUL
OFFICE OF THE CITY COUNCIL
310 CITY HALL
15 WEST KELLOGG BOULEVARD
SAINT PAUL, MN 55102-1615
EMAIL: legislativehearings@ci.stpaul.mn.us
PHONE: (651) 266-8560 FAX: (651) 266-8574

December 27, 2010

Dan Parker
Custom Remodelers Inc.
obo Derrick & Paris Menefee
474 Apollo Drive
Lino Lakes MN 55014

Re: Appeal for property at 442 White Bear Avenue North
File ID: ALH 11-574

Dear Mr. Parker:

This is to confirm that on December 20, 2010, Marcia Moermond, Legislative Hearing Officer, reviewed the above-referenced appeal and recommended granting a 3-inch variance on the openable height of two double hung replacement egress bedroom windows which measured at 21 inches high by 31 inches wide.

If you have further questions, please contact me at 651-266-8563.

Sincerely,

Mai Vang
Legislative Hearing Coordinator

c: Fire Supervisors (email)
Pat Fish (email)
Jim Bloom (email)
Stephen Ubl (email)
Ryan Rehn (email)
File

