



APPLICATION FOR APPEAL

Saint Paul City Clerk
15 W. Kellogg Blvd., 310 City Hall
Saint Paul, Minnesota 55102
Telephone: (651) 266-8688

RECEIVED
JUL 25 2011
CITY CLERK

1. Address of Property being Appealed: <u>1950 Rome Ave</u>	2. Number of Dwelling Units: _____	3. Date of Letter Appealed: <u>8-16-11 - 1:30</u>
--	---------------------------------------	--

4. Name of Owner: Roger Jones

Address: 1950 Rome Ave City: St Paul State: MN Zip: 55106

Phone Numbers: Business _____ Residence 651-699-4533 Cellular _____

Signature: _____

5. Appellant / Applicant (if other than owner): ProBuilt America

Address: 2211 11th Ave E City: N St Paul State: MN Zip: 55109

Phone Numbers: Business 651-770-9315 Residence _____ Cellular _____

Signature: EAB PN

6 State specifically what is being appealed and why (Use an attachment if necessary):

requesting Variance on windows

NOTE: A \$25.00 filing fee made payable to the City of Saint Paul must accompany this application as a necessary condition for filing. You must attach a copy of the original orders and any other correspondence relative to this appeal. Any person unsatisfied by the final decision of the City Council may obtain judicial review by timely filing of an action as provided by law in District Court.

For Office Use Only

Date Received:	Fee Received:	Receipt Number:	Date of Hearing:



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: June 17, 2011

APPEAL PROPERTY ADDRESS: 1950 ROME AVE

APPLICANT NAME: WINDOW WORLD

PHONE NUMBER: 651-770-9315

PERMIT NUMBER: 11 130473

TYPE OF WINDOW

NUMBER OF WINDOWS

Total Glazed Area Minimum 5 Square Feet	5 sq.ft.	Difference from Required Area	Ok
Width of Opening Minimum 20 Inches	15"	Difference from Required Opening	-5"
Height of Opening Minimum 24 Inches	23.5"	Difference from Required Opening	-.5"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	54"	Difference from Maximum Height	-6"

COMMENTS:

Reviewed by: David Tank

FO# _____
ACCT# _____

AMI ASSOCIATED MATERIALS INCORPORATED
WINDOW AND PATIO DOOR ORDER FORM
ALL PRODUCT CONFIGURATIONS MUST BE ORDERED AS VIEWED FROM THE EXTERIOR

Sold To: Charlotte A. Jones
1950 Rome Avenue
St. Paul, MN 55116

Ship To: Window World Twin Cities #86161
2211 - 11th Ave East, Suite #130
North St. Paul, MN 55109-5536
Ph: 651-770-9011, Fax (651) 770-0495

Date: 5-2-11
 Cust PO/Cust Name: 076 8411
 Job Name: Jones Fair

OPTION CODES:

Woodgrain Interiors	Exterior	Mull Type	Grid Options	Screen Options	Glass Op
LO = Light Oak DO = Dark Oak CH = Cherry WH = White FX = Foxwood	AB = American Brown	2 = Double 3 = Triple Q = 1/4, 1/2, 1/4 S = Special	A1 = Colonial Flat Full A2 = Colonial Flat Top Only A3 = Colonial Flat Ends Only A4 = Colonial Flat Center Only NOTE: For other grid options see back of form.	FS = Full Screen LS = Looking Screen NOTE: Fiberglass half screen are standard	LE = Energy Tax Credit LEEP = ClimatePlusElite LE = ClimateTech LEP = ClimateTech Plus LE2 = ClimateTech 2 GT = Gray Tin BT = Bronze T

NOTE: Grooved glass must be specified Book for style and availability

NOTE: Hinge Left (HL) or Hinge Right (HR) on all casement orders as viewed from the exterior. Add "EH" for Egress Hinge.
ALL PRODUCT CONFIGURATIONS MUST BE ORDERED AS VIEWED FROM THE EXTERIOR.

LINE	QTY	MODEL	VINYL COLOR	WDGRN INT/EXT	WIDTH	EXACT WINDOW SIZE	HEIGHT	MULL TYPE	ROOM LOCATION	HINGE OPTION	GLASS OPTION	GRID OPTIONS STYLE	PATTERN	OBS FULL	OBS BOT	TEMP FULL	TEMP BOT	SCREEN	FOAM WRAP	FOAM FILL
1	1	0502	wh	AT	44 3/8	x	28 7/8		W1	1/2	1/2							1/2		X
2	1	0502	wh	AT	44 3/8	x	28 7/8		W1	1/2	1/2							1/2		X
3	1	0502	wh	AT	29 1/4	x	21 5/8		W1	1/2	1/2							1/2		X
4						x														X
5						x														X
6						x														X
7						x														X
8						x														X
9						x														X
10						x														X

SPECIAL INSTRUCTIONS:
All Windows DS Glass

SKETCHES:

White exterior, American Terra Exterior
4-18-11 ERIC TI 4-19