



APPLICATION FOR APPEAL

RECEIVED

OCT 14 2011

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 11-1-11

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1468 Fremont Ave City: _____ State: _____ Zip: _____

Appellant/Applicant: Window World-Esther Dahl Email estherd@windowworldmn.com

Phone Numbers: Business 651-770-9315 Residence _____ Cell _____

Signature: *Esther Dahl* Date: 10/07/11

Name of Owner (if other than Appellant): Chuck Yang

Address (if not Appellant's): same as site

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

Asking for Variance on windows, we are way above minimum for square footage, also home owner built step to correct sill difference for egress



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: September 22, 2011

APPEAL PROPERTY ADDRESS: 1468 FREMONT AVE
APPLICANT NAME: WINDOW WORLD
PHONE NUMBER: 651-770-9315
PERMIT NUMBER: 11 235956
TYPE OF WINDOW: Glider
NUMBER OF WINDOWS: Three

Total Glazed Area Minimum 5 Square Feet	8.4 sq. ft.	Difference from Required Area	+2.7 sq. ft.
Width of Opening Minimum 20 Inches	64"	Difference from Required Opening	+44"
Height of Opening Minimum 24 Inches	19"	Difference from Required Opening	-5"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	61"	Difference from Maximum Height	+ 13"

COMMENTS: Owner has installed a permanent double step for egress height <48" to reuse the original window opening.

Reviewed by: David Nelson