



# APPLICATION FOR APPEAL

RECEIVED

JUN 18 2012

CITY CLERK

Saint Paul City Clerk  
310 City Hall, 15 W. Kellogg Blvd.  
Saint Paul, Minnesota 55102  
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number CASH)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed WALK-IN

**YOUR HEARING Date and Time:**

Tuesday, 6-26-12

Time 1:30 P.M.

Location of Hearing:  
Room 330 City Hall/Courthouse

## Address Being Appealed:

Number & Street: 1640 ROSS AVE City: ST. PAUL State: MN Zip: 55106

Appellant/Applicant: DANIEL ENGLUND JR Email DENGLUNDJR@GMAIL.COM

Phone Numbers: Business 612-618-2640 Residence \_\_\_\_\_ Cell \_\_\_\_\_

Signature: [Signature] Date: 6-18-2012

Name of Owner (if other than Appellant): \_\_\_\_\_

Address (if not Appellant's): \_\_\_\_\_

Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cell \_\_\_\_\_

## What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O \_\_\_\_\_
- Summary/Vehicle Abatement \_\_\_\_\_
- Fire C of O Deficiency List \_\_\_\_\_
- Fire C of O: Only Egress Windows \_\_\_\_\_
- Code Enforcement Correction Notice \_\_\_\_\_
- Vacant Building Registration \_\_\_\_\_
- Other \_\_\_\_\_
- Other \_\_\_\_\_
- Other \_\_\_\_\_



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

## EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: June 13, 2012

APPEAL PROPERTY ADDRESS: 1640 ROSS AVE

APPLICANT NAME: RYAN ROOFING

PHONE NUMBER: 651-501-5969

PERMIT NUMBER: 12 060616

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS One

<b>Total Glazed Area</b> Minimum 5 Square Feet	7.0 sq. ft.	<b>Difference from Required Area</b>	+1.3 sq. ft.
<b>Width of Opening</b> Minimum 20 Inches	24"	<b>Difference from Required Opening</b>	+4"
<b>Height of Opening</b> Minimum 24 Inches	17"	<b>Difference from Required Opening</b>	- 7"
<b>Height of Opening to Finished Floor</b> Maximum 48 Inches for Existing Openings	OK	<b>Difference from Maximum Height</b>	

COMMENTS:

Reviewed by :David Nelson