



APPLICATION FOR APPEAL

RECEIVED
FEB 15 2012
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed *in person*

YOUR HEARING Date and Time:

Tuesday, Feb. 21, 2012

Time 1:30 p.m.

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1572 Wheelock^{Ridge} Rd City: St Paul State: MN Zip: 55130

Appellant/Applicant: The Window Store Home Emp Email Michelle@homesore inc.com

Phone Numbers: Business 612 353-5780 Residence _____ Cell _____

Signature: Derek Tanberg Date: 2-15-12
Tanberg

6044 Central Ave.
Fridley, MN 55432


Name of Owner (if other than Appellant): Ronald Scharpe

Address (if not Appellant's): 1572 Wheelock Ridge Rd St Paul

Phone Numbers: Business _____ Residence 651 779-4521 Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
 - Summary/Vehicle Abatement
 - Fire C of O Deficiency List
 - Fire C of O: Only Egress Windows
 - Code Enforcement Correction Notice
 - Vacant Building Registration
 - Other
 - Other
 - Other
- needs DH windows to keep character of old Home



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: February 15, 2012

APPEAL PROPERTY ADDRESS: 1572 WHEELOCK RIDGE ROAD
APPLICANT NAME: THE WINDOW STORE HOME IMPROVEMENTS INC
PHONE NUMBER: 612-353-5780
PERMIT NUMBER: 12 024327
TYPE OF WINDOW Double Hung
NUMBER OF WINDOWS 2

Total Glazed Area Minimum 5 Square Feet	3.455 sq. ft.	Difference from Required Area	-1.545 sq. ft.
Width of Opening Minimum 20 Inches	31.094"	Difference from Required Opening	+ 11.094"
Height of Opening Minimum 24 Inches	16"	Difference from Required Opening	-8"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	ok	Difference from Maximum Height	ok

COMMENTS:

Reviewed by: DD 2-15-12