

□ Other

APPLICATION FOR APPEAL

Saint Paul City Clerk

JAN U 4 2011

CITY CLERK

310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

R HEARING Date and Time:

The Fig. 18 12 The Filter Date of	AF 5
The City Clerk needs the following to process your apper \$25 filing fee payable to the City of Saint Paul (if cash: receipt number) Copy of the City-issued orders or letter which are being appealed	al: YOUR HEARING Date and Time: Tuesday, [-11-20] Time 1:30
Attachments you may wish to include	Location of Hearing:
This appeal form completed	Room 330 City Hall/Courthouse
	walkin
Address Being Appealed:	
Number & Street: 1019 Carroll Ave	City: St Paul State: WIV Zip: 55104
Appellant/Applicant: Omeri Owe	Email dy dinori anori a Valori lom
Phone Numbers: Business Residence	Cell (212-722-2016
27	
Signature:	Date: _ - c - //
Name of Owner (if other than Appellant):	
Address (if not Appellant's):	***************************************
Phone Numbers: Business Residence	e Cell
What Is Being appealed and wh	ny? Attachments Are Acceptable
Vacate Order/Condemnation/ Revocation of Fire C of O	
□ Summary/Vehicle Abatement	
□ Fire C of O Deficiency List	
□ Fire C of O: Only Egress Windows	
Code Enforcement Correction Notice	nator-dable, It is existing woll and most i
□ Vacant Building Registration	July 1
□ Other	
Other	



CITY OF SAINT PAUL Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220 Saint Paul, Minnesota 55101-1806 Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.strand.gov/dsi

Web: www.stpaul.gov/dsi

- 11

January 3, 2011

OMARI OMARI 5632 36TH AVE S MINNEAPOLIS MN 55417-2906

RE: RE-INSPECTION FIRE CERTIFICATE OF OCCUPANCY WITH DEFICIENCIES 1021 CARROLL AVE

Ref. # 107863

Dear Property Representative:

Your building was re-inspected for the Fire Certificate of Occupancy on January 3, 2011. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected immediately. A reinspection will be made on January 19, 2011 at 2:00 pm.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional reinspection fees.

DEFICIENCY LIST

- 1. 1019 MN Rules 1300.0180 Repair heating appliance as necessary by a licensed contractor. This work may require a permit(s). Call DSI at (651) 266-8989. - Provide inspection and approval of heating system installed without permit.
- 2. 1021 SPLC 34.11 (5), 34.34 (2) Contact a licensed contractor to repair or replace the water heater. This work may require a permit(s). Call DSI at (651) 266-9090. Provide inspection and approval of water heater installed without permit.
- 3. SPLC 34.11 (6), 34.34 (3) Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
- 4. SPLC 39.02(c) Complete and sign the provided smoke detector affidavit and return it to this office.

5. SPLC 34.19 - Provide access to the inspector to all areas of the building. - Provide access for re-inspection on January 19, 2011 at 2:00 pm.

For an explanation or information on some of the violations contained in this report, please visit our web page at: http://www.ci.stpaul.mn.us/index.aspx?NID=211

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at mitchell.imbertson@ci.stpaul.mn.us or call me at 651-266-8986 between 7:30 a.m - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Mitchell Imbertson Fire Inspection Ref. # 107863



CITY OF SAINT PAUL Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220 St Paul, Minnesota 55101-1806 Telephone: 651-260-80-06 Facsimile: 651-260-9624 Web: www.stpanl.gov.do

October 25, 2010

Legend Mechanical 8555 W 123rd St Savage Mn 55378

Address: 1019 Carroll Ave Permit #: 10 908672 WRM

Correction Notice

To Whom It May Concern:

The referenced installation has been found not in compliance and cannot be accepted for the following reasons:



- 1) The IFGC vent tables require double-wall vent connector from the furnace to the vertical vent. This would require a double-wall wye-branch fitting to accomodate the water heater venting.
- 2) A metallic chimney liner is required for this installation. Since the liner isn't visible at the top of the tile lined chimney, a letter, on company stationery must be submitted to our office which verifies (in writing) that one exists.
- 3) The combustion air inlet hood is within 3 ft. of the dryer vent termination. Relocate, to maintain the 3 ft. minimum.

*** please call the mechanical inspector to arrange his inspection

Please correct the above conditions and notify me in writing within 30 days that the job is ready for re-inspection. If you have any questions, please call me at the number below.

Sincerely,

Jon Knudson

Warm Air Inspector

Direct Line: 651-266-9062

E-Mail: jon.knudson@ci.stpaul.mn.us



December 27, 2010

Reference:

1019 Carroll Ave

St. Paul, MN

Subject:

Mechanical Proposal

After reviewing the scope of work, we are pleased to present the following HVAC proposal for the above-referenced project. Our scope of work includes the following:

HVAC Scope:

- Provide correction notice repairs from the city of St. Paul letter.
- Provide mechanical permit(s) required.
- Provide all hoisting, rigging, and rentals.

Thank you,

Tony Goze tonyg@legendmechanical.com 612-432-5512

Fax: (952) 818-8503