



APPLICATION FOR APPEAL

Saint Paul City Council – Legislative Hearings

RECEIVED

OCT 16 2024

CITY CLERK

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8585

legislativehearings@ci.stpaul.mn.us

We need the following to process your appeal:

\$25 filing fee (non-refundable) (payable to the City of Saint Paul) (if cash: receipt number 885584)

Copy of the City-issued orders/letter being appealed & any attachments you may wish to include

Walk In Mail Email

Appeal taken by: _____

HEARING DATE & TIME

(provided by Legislative Hearing staff)

Tuesday, October 22, 2024

Location of Hearing:

Telephone: you will be called between _____ & _____

In person (Room 330 City Hall) at: 1:30 p.m.
(required for all condemnation orders and Fire C of O revocations and orders to vacate)

Address Being Appealed:

Number & Street: 511 Minnehaha Ave E City: St. Paul State: MN Zip: 55130

Appellant/Applicant: Jerry A. Brashier Email: jerry.a.brashier@gmail.com

Phone Numbers: Business _____ Residence _____ Cell 612-385-8707

Signature: [Handwritten Signature] Date: 10-16-2024

Name of Owner (if other than Appellant): _____

Mailing Address if Not Appellant's: _____

Phone Numbers: Residence _____ Cell 612-385-8707

What is being appealed and Why? Attachments Are Acceptable

Vacate Order/Condemnation/Revocation of Fire C of O

Summary/Vehicle Abatement

Fire C of O Deficiency List/Correction

Code Enforcement Correction Notice

Vacant Building Registration

Other (Fence Variance, Code Compliance, etc.)

~~The Department's~~ Permits needed work was not done // All Exterior requested Work was Done // Backyard fire pit was removed
NO Windows were installed.



October 14, 2024

Jerry Anthony Brashier
885 12th St
Newport MN 55055-1736

Revocation of Fire Certificate of Occupancy and Order to Vacate

RE: 511 MINNEHAHA AVE E
Ref. # 10051

Dear Property Representative:

Your building was inspected on September 16, 2024, for the renewal of the Certificate of Occupancy. Since you have failed to comply with the applicable requirements, it has become necessary to revoke the Certificate of Occupancy in accordance with Section 40.06 of the Saint Paul Legislative Code.

A reinspection will be made on November 1, 2024, at 10:30 am or the property vacated.

The Saint Paul Legislative Code further provides that no building shall be occupied without a Certificate of Occupancy. Failure to immediately complete the following deficiency list or the building vacated may result in a criminal citation.

DEFICIENCY LIST

1. Backyard - MSFC 307.4 - All fires on the ground must be a minimum of 25 feet from structures or contained in a grill or outdoor fireplace. Wind speeds must be under 10 mph, constantly attended, a means of extinguishment must be provided. Only natural firewood can be burned (no construction materials| brush or waste materials), and fire shall be extinguished if the smoke is deemed a nuisance. A citation will be issued for non-compliance. -Fire pit in the back yard does not meet requirements - remove fire pit and discontinue burning

2. Exterior - Walls - SPLC 34.09 (1)(2)(a), 34.33 (1)(b) - Provide and maintain all exterior walls free from holes and deterioration. All wood exterior unprotected surfaces must be painted or protected from the elements and maintained in a professional manner free from chipped or peeling paint. -Trim boards along roof and front fascia chipped and peeling paint, boards are water damaged or missing - repair or replace boards - exposed boards where fascia and trim have been removed - hole in brick where trim boards have been removed along the roof line in rear of property
3. Exterior - SPLC 34.09 (4), 34.33 (3)- Repair and maintain the window in good condition. All windows shall be maintained in accordance with the building code in effect at the time of construction or as altered/modified under an approved building permit. -Multiple windows installed without permit
4. MSBC - Section 1300.0120 Part 1 - Permits Required. Any owner or authorized agent who intends to construct, enlarge, alter, repair, move, demolish, or change the occupancy of a building or structure, or to erect, install, enlarge, alter, repair, remove, convert or replace any electrical, gas, mechanical or plumbing system, the installation of which is regulated by this code, or to cause any such work to be done, shall first make application to the building official and obtain the required permit. Work being done requires a permit. -Windows being replaced - no permit on file - permit shall be pulled, work inspected, and the permit closed
5. SPLC Sec. 40.06. - Suspension, revocation, and denial; (3) If it is found upon inspection of the fire code official that the building or occupancy is in violation of provisions of this or other applicable safety codes, ordinances, rules and regulations-Revoked for but not limited to long term non-compliance in completing Correction Orders from inspections that took place on 12/26/2023, 01/26/2024, 02/02/2024, 06/12/2024, 07/22/2024, and 09/16/2024
6. SPLC 39.02(c) - Complete and sign the smoke alarm affidavit and return it to this office.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>.

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: Daryl.Chute@ci.stpaul.mn.us or call me at 651-266-9129 between 7:30 - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Daryl Chute
Fire Safety Inspector II

Ref. # 10051