



# APPLICATION FOR APPEAL

RECEIVED

JAN 00 2012

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

**The City Clerk needs the following to process your appeal:**

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number \_\_\_\_\_)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed *walk-in*

**YOUR HEARING Date and Time:**

Tuesday, 1-17-12

Time 1:30

Location of Hearing:  
Room 330 City Hall/Courthouse

## Address Being Appealed:

Number & Street: 1046 Stinson St City: St Paul State: MN Zip: 55103

Appellant/Applicant: The window store Home Inc Email Michelle@homesureinc.com

Phone Numbers: Business 612 353-5780 Residence \_\_\_\_\_ Cell 763 477-1820

Signature: Derek Jamberg Date: 1-5-12

Name of Owner (if other than Appellant): Julie Rohlik

Address (if not Appellant's): 1046 Stinson St St Paul

Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cell 651 295-2617

## What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

these windows just miss  
on qualifying for egress.  
Julie Rohlik doesn't want  
2 windows in the house to  
miss match the rest of her  
new windows.



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

**EGRESS WINDOW NON-COMPLIANCE DETERMINATION**

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: January 6, 2012

APPEAL PROPERTY ADDRESS: 1046 STINSON ST

APPLICANT NAME: THE WINDOW STORE HOME IMPROVEMENTS INC

PHONE NUMBER: 612-353-5780

PERMIT NUMBER: 11 312950

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 2

<b>Total Glazed Area</b> Minimum 5 Square Feet	3.56	<b>Difference from Required Area</b>	- 1.44
<b>Width of Opening</b> Minimum 20 Inches	23.34	<b>Difference from Required Opening</b>	+ 3.34
<b>Height of Opening</b> Minimum 24 Inches	22	<b>Difference from Required Opening</b>	-2
<b>Height of Opening to Finished Floor</b> Maximum 48 Inches for Existing Openings	<48	<b>Difference from Maximum Height</b>	OK

COMMENTS: N/A

Reviewed by: J HOFFMAN 1-6-12