



CITY OF SAINT PAUL  
*Christopher B. Coleman, Mayor*

375 Jackson Street, Suite 220  
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989  
Facsimile: 651-266-8951  
Web: [www.stpaul.gov/dsi](http://www.stpaul.gov/dsi)

January 24, 2018

REIMAGINE REAL ESTATE  
540 LAKE ST  
EXCELSIOR MN 55331 USA

## FIRE INSPECTION CORRECTION NOTICE

RE: 1087 RANDOLPH AVE  
Ref. #106861

Dear Property Representative:

Your building was inspected on January 8, 2018 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date. **A re-inspection will be made on February 2, 2018 at 1:30 pm.**

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

**YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.**

### DEFICIENCY LIST

1. Rear of building - MSFC 505.1 - Provide address numbers on building.-
2. Thru-out - SPLC 34.10 (6), 34.34 (5) - Exterminate and control insects, rodents or other pests. Provide documentation of extermination.-Mice

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: [mike.cassidy@ci.stpaul.mn.us](mailto:mike.cassidy@ci.stpaul.mn.us) or call me at 651-266-8984 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Mike Cassidy  
Fire Inspector

Reference Number 106861