



APPLICATION FOR APPEAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

RECEIVED

NOV 01 2010

CITY CLERK

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, NOV. 9

Time 1:30

Location of Hearing:
Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 2047 Margaret St City: St. Paul State: MN Zip: 55119

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

Signature: [Signature] Date: _____

Name of Owner (if other than Appellant): Doug Earl

Address (if not Appellant's): 2047 Margaret St

Phone Numbers: Business 651-736-9310 Residence 651-731-2511 Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are appealing 4 replacement windows that will not comply w/ Egress Policy. Current dimensions will be 1" short in operable height; operable width and overall glazed area will be exceeded. Please Approve



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: October 28, 2010

APPEAL PROPERTY ADDRESS: 2047 MARGARET ST
APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION
PHONE NUMBER: 651-266-9071
PERMIT NUMBER: 10 915607
TYPE OF WINDOW: Double hung
NUMBER OF WINDOWS: 4

Total Glazed Area	13.4 <i>sqft</i>	Difference from Required Area	+8.4 <i>sqft</i>
Width of Opening	31 "	Difference from Required Opening	+11 "
Height of Opening	23 "	Difference from Required Opening	-1 "
Height of Opening to Finished Floor	36	Difference from Maximum Height	ok

COMMENTS: With the information provided above approval is recommended. 10-29-10 rr

Reviewed by: Rehn