



APPLICATION FOR APPEAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

RECEIVED

MAY 24 2012

CITY CLERK

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR Mail-In

YOUR HEARING Date and Time:

Tuesday, 6-12-12

Time 1:30 P.M.

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 816 Oakland Ave. City: St. Paul State: Mn Zip: 55104

Appellant/Applicant: Kent Peterson Email KENTSLAKE@GMAIL.COM

Phone Numbers: Business 651-260-1709 Residence same Cell same

Signature: Kent Peterson Date: 5/23/12

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why?

Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

May 18, 2012

KENT PETERSON
6510 12TH AVE S
RICHFIELD MN 55423

FIRE INSPECTION CORRECTION NOTICE

RE: 816 ASHLAND AVE
Ref. #107958
Residential Class: B

Dear Property Representative:

Your building was inspected on May 18, 2012 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date.

A re-inspection will be made on June 21, 2012 at 1:00PM.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

1. MSFC 605.6 - Provide electrical cover plates to all outlets, switches and junction boxes where missing. REPLACE OUTLET COVERS IN GARAGE.
2. SPLC 34.10 (3), 34.33(2) - Repair or replace the damaged handrail in an approved manner. IN REAR STAIRWAY LEADING TO SECOND FLOOR.
3. MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height

not more than 48 inches. This work will require permit(s). Call DSI at (651)- 266-9090.
UPPER UNIT: 32 IN WIDE X 17 IN HIGH, DH, 45 IN WIDE X 17 IN HIGH DH

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: michael.efferson@ci.stpaul.mn.us or call me at 651-266-8981 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Michael Efferson
Fire Inspector

Reference Number 107958