

Scanned



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 5-29-12

APPEAL PROPERTY ADDRESS: 1263 CHARLES AVE
APPLICANT NAME: RUSHLI HEALTH (DANIEL SCHMIDT) PHONE NUMBER: 266-1143

PERMIT NUMBER: _____

TYPE OF WINDOW: DOUBLE HUNG (VINYL)

NUMBER OF WINDOWS: 2

TOTAL GLAZED AREA: 8.3 sq' DIFFERENCE FROM REQUIRED AREA: Comp
WIDTH OF OPENING: 23.2" DIFFERENCE FROM REQUIRED OPENING: Comp
HEIGHT OF OPENING: 19.93" DIFFERENCE FROM REQUIRED OPENING: 4.07"
HEIGHT OF OPENING TO FINISHED FLOOR: 4'10" DIFFERENCE FROM MAXIMUM HEIGHT: Comp

RECOMMENDATION (IF APPLICABLE): _____

FROM: _____

RECEIVED
MAY 29 2012
CITY CLERK

LH: 6-12-12
1:30 P.M

Faxed 5-29-12
by LS

Select a Model
 (Model D201)
 Excalibur Double Hung

Min. W: 13	Max. W: 57	Min. H: 29	Max. H: 84	Min. U: 122
Top Sash Width	24.5760	Part Size	Width: 27.625	Height: 53.325
Bottom Sash Width	25.1760	Exhaust	Select Exhaust	For Arch/Top Models Only
Top Glass Width	22.6875	Opening	Part Size	Type: Standard
Bottom Glass Width	23.4575	Screen	1.6	Glass: Double Strength (3 mm)
Top Glass Height	23.6875	<input type="checkbox"/> All Sash Calculated		
Bottom Glass Height	24.3750			
Screen Width	21.9375			
Screen Height	19.4375			
Top Sash Weight (Plus 5 lb)	20 lb			
Top Balance Size (C.F.)	10 PK			
Top Balance Size (Panel)	21.49			
Bottom Sash Weight	16 lb			
Bottom Balance Size (C.F.)	8 LG			
Bottom Balance Size (Panel)	25.45			
Egress Opening Width	23.2190			
Egress Opening Height	19.9375			
Egress Opening Area (sq.ft.)	3.3190			

Scanned

Saint Paul - Ramsey County Department of Public Health

Environmental Health Section

2785 White Bear Avenue North Suite 350

Maplewood, MN 55109-1320

FAX: (651) 266-1177

Date: 6-12-12 8:11:30 a.m.

FACSIMILE TRANSMISSION

Cover Sheet and Transmittal Form

RECEIVED

MAY 29 2012

CITY CLERK

To FAX#: 6-8574

To: Mai Yang, Paralegal

Location: Legislative Hearing Office
City of St. Paul

Sender: Daniel Schmidt / Jim Vannorelly
St. Paul - Ramsey Cty. Dept. of Public Health

This transmission consists of _____ pages (including cover sheet).

If transmission is incomplete or illegible, call sender at (651) 266-1143 (DANIEL SCHMIDT)

Message:

Request for Egress Window Non-Compliance Determination

Attachments: Egress Window Non-Compliance Determination Form

CONFIDENTIALITY NOTICE

The document(s) accompanying this facsimile transmission may contain confidential information intended only for the use of the recipient named above. If you are not the intended recipient, you are hereby notified that any disclosure, copying or distribution of the contents of this transmission except its direct delivery to the intended recipient is strictly prohibited. If you have received this transmission in error, please notify us immediately by telephone to arrange for return of the original message to us.