

**Date:** January 26, 2018  
**File #:** 18 - 022495  
**Folder Name:** 1272 EDGERTON ST  
**PIN:** 202922430031



## Fire Inspection Report

**City of Saint Paul**  
 Department of Safety and Inspections  
 375 Jackson Street - Suite 220  
 Saint Paul MN 55101-1806

**Owner Name** Covenant Capital LLC  
**Owner Address** 2300 Jarvis Hills Drive  
**City State Zip** Little Canada  
**Owner Phone** (763) 442-2541 Scott

**License** \_\_\_\_\_  
**Complaint** \_\_\_\_\_  
**C of O** \_\_\_\_\_  
**Date** \_\_\_\_\_

**Building Address:** 1272 Edgerton St, St Paul

You are hereby notified to remedy the conditions stated below immediately. A reinspection will be made after the reinspection date stated below. If you consider any of these code requirements to be unreasonable, you may appeal to the Legislative Hearing Officer. Applications for appeals may be obtained at the City Clerks Office, 170 City Hall 651-266-8989 within 10 days of the date of the original orders.

Code	Conditions to be Corrected
MS299F.302	Maintain working smoke detectors
34.11.6	Maintain adequate heat (68°F) in all habitable rooms

**Owner or Representative Signature** \_\_\_\_\_  
**Occupancy Type** R-3      **Inspector Signature** [Signature]  
**CEO Key** \_\_\_\_\_      **Reinspection Date** 1/26/18

**Date:** January 26, 2018  
**File #:** 18 - 022495  
**Folder Name:** 1272 EDGERTON ST  
**PIN:** 202922430031



**Date:** January 26, 2018  
**File #:** 18 - 022495  
**Folder Name:** 1272 EDGERTON ST  
**PIN:** 202922430031

