



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 5-31-11

APPEAL PROPERTY ADDRESS: 1893 Sheridan

APPLICANT NAME: _____ PHONE NUMBER: _____

PERMIT NUMBER: _____

TYPE OF WINDOW: DH

NUMBER OF WINDOWS: 3 - 1 per bedroom

TOTAL GLAZED AREA: 7.9 sq ft

DIFFERENCE FROM REQUIRED AREA: + 2.9 sq ft

WIDTH OF OPENING: 24"

DIFFERENCE FROM REQUIRED OPENING: + 4"

HEIGHT OF OPENING: 20"

DIFFERENCE FROM REQUIRED OPENING: - 4"

HEIGHT OF OPENING TO FINISHED FLOOR: 28"

DIFFERENCE FROM MAXIMUM HEIGHT: - 20"

COMMENTS: _____

FROM: Ben Eggers