



APPLICATION FOR APPEAL

RECEIVED
FEB 23 2011
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 3-8-11

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 675 E Arlington Ave City: Saint Paul State: MN Zip: 55106

Appellant/Applicant: Window Concepts of MN Email _____

Phone Numbers: Business 6519050105 Residence _____ Cell _____

Signature: Jeanne Beum Date: 2/21/11

Name of Owner (if other than Appellant): Donald Wright

Address (if not Appellant's): 675 E. Arlington Ave

Phone Numbers: Business _____ Residence 6517634000 Cell _____

What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

State code states that all windows that are replaced with same size & style are grandfathered in and meet code



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: February 16, 2011

APPEAL PROPERTY ADDRESS: 675 ARLINGTON AVE E

APPLICANT NAME: WINDOW CONCEPTS OF MINNESOTA INC

PHONE NUMBER: 651-266-9023

PERMIT NUMBER: 10 936721

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 1

Total Glazed Area Minimum 5 Square Feet	11.5 sq. ft.	Difference from Required Area	+5.81 sq. ft.
Width of Opening Minimum 20 Inches	28.75 in.	Difference from Required Opening	+8.75 in.
Height of Opening Minimum 24 Inches	19.75 in.	Difference from Required Opening	-4.25 in.
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	28 in.	Difference from Maximum Height	+20 in.

COMMENTS:

Reviewed by: Virgil Thomas