



# APPLICATION FOR APPEAL

RECEIVED

Saint Paul City Clerk

FEB 14 2011

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

CITY CLERK

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number \_\_\_\_\_)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 3-1-11

Time 1:30

Location of Hearing:  
Room 330 City Hall/Courthouse

## Address Being Appealed:

#77131160

Number & Street: 1485 Edgumbe Rd City: St. Paul State: MA Zip: 55116

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence \_\_\_\_\_ Cell \_\_\_\_\_

Signature: [Signature] Date: \_\_\_\_\_

Name of Owner (if other than Appellant): Keerie/Fred Lounsbury

Address (if not Appellant's): 1485 Edgumbe Rd

Phone Numbers: Business \_\_\_\_\_ Residence 651-207-8707 Cell \_\_\_\_\_

## What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are appealing 8 double hung replacement windows that will not comply w/ Egress Policy. Windows will be short in operable height. Operable width and overall glazed area is exceeded. Homeowner would like to keep style consistent throughout house. 23 windows being replaced in total. Please Approve.

Revised 8/20/2010



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

**EGRESS WINDOW NON-COMPLIANCE DETERMINATION**

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: February 4, 2011

APPEAL PROPERTY ADDRESS: 1485 EDGCUMBE ROAD  
APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION  
PHONE NUMBER: 651-266-9071  
PERMIT NUMBER: 11 012687  
TYPE OF WINDOW: Double Hung  
NUMBER OF WINDOWS: 8

<b>Total Glazed Area</b> Minimum 5 Square Feet	9.4	<b>Difference from Required Area</b>	+4.4
<b>Width of Opening</b> Minimum 20 Inches	26	<b>Difference from Required Opening</b>	+6
<b>Height of Opening</b> Minimum 24 Inches	18 7/8	<b>Difference from Required Opening</b>	-5 1/8
<b>Height of Opening to Finished Floor</b> Maximum 48 Inches for Existing Openings	36	<b>Difference from Maximum Height</b>	ok

COMMENTS: With the information provided above approval is recommended. 2-4-11 rr

Reviewed by: Rehn