

□ Other

APPLICATION FOR APPEAL

RECEIVED

NOV 2 2 2010

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd. Saint Paul, Minnesota 55102 Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:			YOUR HEARING Date and Time:			
~	\$25 filing fee payable to the City of S	Saint Paul	(21-12			
X	(if cash: receipt number)		Tuesday, 13/7/0			
	Copy of the City-issued orders or let	ter which	Tuesday, 13/7/0 Time			
ш	are being appealed		Time / DU			
X	Attachments you may wish to includ	e	Location of Hearing:			
×	This appeal form completed		Room 330 City Hall/Co	ourthouse		
A	ddress Being Appeal	ed:				
Nı	umber & Street: 1370 Prosperit	y Ave City: St.	. Paul State. MN	Zip: 55106		
Number & Street: 1370 Prosperity Ave City: St. Paul State: MN Zip: 55106 Appellant/Applicant: Beissel Window and Siding, Co Email jeff@beisselwindows.com						
Phone Numbers: Business 651-451-6835 Residence Cell						
Sig	me of Owner (if other than Appellant):	Bersel	Date: NOvmebe	er 19, 2010		
Address (if not Appellant's): 731 Camberwell Drive, St. Paul, MN 55123						
Pho	one Numbers: Business	Residence	Cell			
What Is Being appealed and why? Attachments Are Acceptable Vacate Order/Condemnation/						
	Revocation of Fire C of O					
	Summary/Vehicle Abatement					
	Fire C of O Deficiency List					
	Fire C of O: Only Egress Windows					
	Code Enforcement Correction Notice		The second secon			
	Vacant Building Registration	**************************************				
x (Other Egress variance	see attached				
	Other	200 00000000				



CITY OF SAINT PAUL INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK 15 KELLOGG BLVD. WEST 310 CITY HALL SAINT PAUL, MN 55102

PHONE: 651-266-8688 FAX: 651-266-8574

DATE: November 8, 2010

APPEAL PROPERTY ADDRESS: 1370 PROSPERITY AVE

APPLICANT NAME:

BEISSEL WINDOW & SIDING CO

PHONE NUMBER:

651-266-9071

PERMIT NUMBER:

10 916579

TYPE OF WINDOW

Casement

NUMBER OF WINDOWS

1

Total Glazed Area	5.5	Difference from Required Area	+.5
Width of Opening	19	Difference from Required Opening	-1
Height of Opening	41	Difference from Required Opening	+17
Height of Opening to Finished Floor	35	Difference from Maximum Height	+9

COMMENTS: With the information provided above, approval is recommended. 11-8-10 rr

Reviewed by: Rehn