



SAINT PAUL
SAFETY & INSPECTIONS

Department of Safety and Inspections (DSI)
Angie Wiese, PE (MN), CBO, DIRECTOR

375 Jackson Street, Suite 220
St. Paul, Minnesota 55101-1806
Phone: 651-266-8989 Fax: 651-266-8951
Visit our website at www.stpaul.gov/dsi

Yog hais tias joj tsis to taub tsab ntway no, hu rau ntawm (651) 266-8989. Lawv mam nrhiav ib tug neeg txhais lus los pab koj.

Parker Hoen
1635 Montreal Ave
St Paul, MN 55116

REVISED CORRECTION NOTICE

Date: September 25, 2025
RE: 1635 Montreal Ave

Dear Sir/Madam:

The City of Saint Paul, Department of Safety and Inspections has inspected the above referenced property on **August 14, 2025** and has determined that the following deficiencies exist in violation of the Saint Paul Legislative Code.

1. SPLC 45.03. – **NUISANCE/ DRAINAGE:** Please re-direct your drainage away from the public sidewalk/street. Your current direction is causing a nuisance and you are not authorized to have discharge to any street, sidewalk, alley, or right-of-way. This interferes or renders dangerous for passage on the public sidewalk, street, or alley.

YOU ARE NOT ALLOWED TO DRAIN YOUR GUTTERS ONTO THE CITY RIGHT-OF-WAY.

PLEASE IMMEDIATELY REMOVE THE UNDERGROUND PVC PIPES THAT ARE RUNNING UNDER THE RETAINING WALL/ FENCE AND ONTO THE CITY RIGHT-OF-WAY.

YOUR DOWNSPOUT DISCHARGE MUST BE DIRECTED TO THE FRONT AND REAR YARD AND NOT TOWARD THE PROPERTY BOUNDARY. THANK YOU.

You are hereby notified to correct these deficiencies in accordance with the appropriate codes. The enforcement Officer will re-inspect these premises on or after **October 2, 2025**, by which date the violations noted must be corrected. Failure to correct these deficiencies may result in an abatement and /or additional fees for re-inspection.

You may file an appeal to this notice by contacting the City Clerk's Office at (651) 266-8585. Any appeal must be made in writing within 10 days of the date of this notice. (You must submit a copy of this Notice when you appeal and pay a filing fee.)

If you have any questions or request additional information concerning this matter, please contact Inspector Richard Kedrowski, at (651) 266-9141. To arrange an appointment or request an extension of time to complete repairs, you will need to speak directly to the inspector.

Sincerely,

Richard Kedrowski
Enforcement Officer
Badge No: 320

Footnote:

To see the legislative Code go to www.stpaul.gov on the internet, click on "Departments", then click on "Department of Safety and Inspections", scroll down the page for the "Codes". Most Correction Notices derive from Chapter 34.

***WARNING:** Code inspection and enforcement trips cost the taxpayers money. If multiple trips within a year to your property are required to ensure compliance with the law, you may be charged for the cost of inspections and enforcement trips to your property. Such charges are in addition to any other fines or assessments which may be levied against you and your property.