



# APPLICATION FOR APPEAL

RECEIVED  
MAY 14 2012  
CITY CLERK

Saint Paul City Clerk  
310 City Hall, 15 W. Kellogg Blvd.  
Saint Paul, Minnesota 55102  
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number \_\_\_\_\_)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR  Mail-In

<b>YOUR HEARING Date and Time:</b>
Tuesday, <u>5-22-12</u>
Time <u>1:30 P.M.</u>
<b>Location of Hearing:</b>
<u>Room 330 City Hall/Courthouse</u>

**Address Being Appealed:** 424 Banfil

Number & Street: 998 <sup>home:</sup> Bronty City: St Paul State: MN Zip: 55109

Appellant/Applicant: Rob Menic Email: \_\_\_\_\_

Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cell \_\_\_\_\_

Signature: [Signature] Date: 5/14/2012

Name of Owner (if other than Appellant): \_\_\_\_\_

Address (if not Appellant's): \_\_\_\_\_

Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cell \_\_\_\_\_

## What Is Being Appealed and Why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/
- Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other

driveway



CITY OF SAINT PAUL  
*Christopher B. Coleman, Mayor*

375 Jackson Street, Suite 220  
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989  
Facsimile: 651-266-8951  
Web: [www.stpaul.gov/dsi](http://www.stpaul.gov/dsi)

May 10, 2012

ROBERT LOUIS MENIER  
998 ARMSTRONG AVE  
ST PAUL MN 55102-3741

### FIRE INSPECTION CORRECTION NOTICE

RE: 424 BANFIL ST  
Ref. #106023  
Residential Class: B

Dear Property Representative:

Your building was inspected on May 10, 2012 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date.

**A re-inspection will be made on June 15, 2012 at 10:00AM.**

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

#### DEFICIENCY LIST

1. EXTERIOR - SPLC 34.08 (7) - All parking spaces shall be paved with asphalt, concrete, or durable dustless surfacing. Before any existing spaces may be paved, site plan approval must be obtained as specified in the St. Paul Zoning Code. Contact DSI Zoning at 651-266-9090.
2. EXTERIOR - SPLC 34.09 (2), 34.32(2) - Repair or replace the unsafe rear stairway. There's a hole in the concrete tread and needs to be repaired in an approved manner. This work may require a permit(s). Call DSI at (651) 266-9090.

3. EXTERIOR - SPLC 34.09 (3), 34.32 (3) - Provide or repair and maintain the window screen.
4. EXTERIOR - UMC 504.6 - Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter. This work may require a permit(s). Call DSI at (651) 266-8989.- PROVIDE EXTERIOR WEATHER CAP FOR DRYER DUCT TERMINATION AT BASEMENT WINDOW.
5. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
6. SPLC 39.02(c) - Complete and sign the smoke detector affidavit and return it to this office.
7. SPLC 34.19 - **Provide access to the inspector to all areas of the building.**

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: [michael.efferson@ci.stpaul.mn.us](mailto:michael.efferson@ci.stpaul.mn.us) or call me at 651-266-8981 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Michael Efferson  
Fire Inspector

---

Reference Number 106023