



APPLICATION FOR APPEAL

RECEIVED
OCT 31 2011
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR Mail-In

YOUR HEARING Date and Time:
Tuesday, <u>11-8-11</u>
Time <u>11:00 a.m.</u>
Location of Hearing: <u>Room 330 City Hall/Courthouse</u>

Address Being Appealed:

Number & Street: 1658 Maryland Ave E City: St. Paul State: MN Zip: 55106

Appellant/Applicant: Michael Dupont Email almfdupont@gmail.com

Phone Numbers: Business _____ Residence _____ Cell 612-839-8777

Signature: [Handwritten Signature] Date: 10/31/11

Name of Owner (if other than Appellant): Dudley Sankey

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other

Me, my wife and child are living at the property.



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

September 14, 2011

DUDLEY SANKEY
LEE V SANKEY
11946 ELDORADO ST NW
COON RAPIDS MN 55433-1620

Revocation of Fire Certificate of Occupancy and Order to Vacate

RE: 1658 MARYLAND AVE E
Ref. # 100618

Dear Property Representative: You will need a permit for dryer duct . This permit has to be obtained at DSI and needs to be finalized by close of business on September 22, 2011

Your building was inspected on September 14, 2011, for the renewal of the Certificate of Occupancy. Since you have failed to comply with the applicable requirements, it has become necessary to revoke the Certificate of Occupancy in accordance with Section 33.05 of the Saint Paul Legislative Code. A reinspection will be made on September 22, 2011 or the property vacated.

The Saint Paul Legislative Code further provides that no building shall be occupied without a Certificate of Occupancy. Failure to immediately complete the following deficiency list or the building vacated may result in a criminal citation.

DEFICIENCY LIST

1. SPLC 39.02(c) - Complete and sign the provided smoke detector affidavit and return it to this office.
2. UMC 504.6 - Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter. This work will require a permit(s). Call DSI at (651) 266-8989.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: james.thomas@ci.stpaul.mn.us or call me at 651-266-8983 between 7:30 - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

James Thomas
Fire Inspector

Ref. # 100618

By Order of the
City of Saint Paul
Department of Safety & Inspections
Fire Inspection Division
651- 266- 8989

REVOCAATION NOTICE

The Fire Certificate of Occupancy Required for
The Occupancy or Use of This Building, Has been
Revoked. It is unlawful to Use or Occupy this
Building After: 10-31-11 at 12 NOON

Persons Using or Allowing the Use or Occupancy of
This Building are Subject to Criminal Penalties.

Building Address: 1058 E. Maryland

Code: SPLC, Art.: 40, Sect. 06.

Inspector: JTHO MAS, Date: 10-27-11.

Any Person affected by this Order, may file an appeal at the Office of the City Clerk,
Room 310, City Hall, 15 Kellogg Blvd. West, or call (651) 266-8688 within 10 days
of the original notice. The cost to file an appeal is \$25.00 and must include a copy
of the letter of revocation. This letter of revocation is available at: Saint Paul Department
of Safety & Inspections, Fire Inspection Division, 375 Jackson Street Suite #200 Saint Paul, MN 55101