

Moermond, Marcia (CI-StPaul)

From: Ubl, Stephen (CI-StPaul)
Sent: Friday, September 02, 2016 8:24 AM
To: Moermond, Marcia (CI-StPaul)
Subject: 606 Bush

Marcia,

The owner was given orders to insulate the ductwork in the crawl space of the home OR condition the crawl space as part of the basement. This “conditioning” includes insulating the walls, installing a moisture barrier on the crawl space floor and installing heat registers in the crawl space.

It is his choice which path he chooses to satisfy the code. To date, he has not completed either path!



Stephen Ubl

City of St. Paul Building Official

Department of Safety & Inspections

375 Jackson St

Saint Paul, MN 55101

P: 651-266-9021

F: 651-266-9099

stephen.ubl@ci.stpaul.mn.us

The Most Livable
City in America



Making Saint Paul the Most Livable City in America