



# APPLICATION FOR APPEAL

RECEIVED  
NOV 24 2010  
CITY CLERK

Saint Paul City Clerk  
310 City Hall, 15 W. Kellogg Blvd.  
Saint Paul, Minnesota 55102  
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number \_\_\_\_\_)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

<b>YOUR HEARING Date and Time:</b>
Tuesday, <u>Dec. 14, 2010</u>
Time <u>1:30 P.M.</u>
<b>Location of Hearing:</b>
<u>Room 330 City Hall/Courthouse</u>

## Address Being Appealed:

Number & Street: 745 Hoyt Ave City: St Paul State: MN Zip: 55106  
 Appellant/Applicant: Custom Remodelers Inc. Email: Judy.h@customremodelersinc.com  
 Dan Parker  
 Phone Numbers: Business 651-784-2646 Residence \_\_\_\_\_ Cell \_\_\_\_\_  
 Signature: [Signature] Date: 11-24-2010  
 Name of Owner (if other than Appellant): Drew + Rachel Wale  
 Address (if not Appellant's): \_\_\_\_\_  
 Phone Numbers: Business 651-206-5910 Residence \_\_\_\_\_ Cell \_\_\_\_\_

## What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

Permit # 2010017746  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

**EGRESS WINDOW NON-COMPLIANCE DETERMINATION**

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: 07-30-10

APPEAL PROPERTY ADDRESS: 745 HOYT

APPLICANT NAME: CUSTOM REMODELERS INC. PHONE NUMBER: \_\_\_\_\_

PERMIT NUMBER: 2010017746

DEFICIENT WINDOW OPENINGS	WINDOW #1	WINDOW #2	WINDOW #3	WINDOW #4
TYPE OF WINDOW	Double-Hung	Double-Hung		
NUMBER OF WINDOWS	2	1		
TOTAL GLAZED AREA	13.5 SQ FT.	10.1 SQ FT.		
DIFFERENCE FROM REQUIRED AREA	+7.5SQ FT.	+4.4 SQ FT.		
WIDTH OF OPENING	31.25 "	27..25"		
DIFFERENCE FROM REQUIRED OPENING	+11.25 "	+7.25 "		
HEIGHT OF OPENING	21"	17"		
DIFFERENCE FROM REQUIRED OPENING	-3"	-7"		
HEIGHT OF SILL TO FINISHED FLOOR	28"	35"		
DIFFERENCE FROM MAXIMUM HEIGHT	+20"	+13		

COMMENTS: \_\_\_\_\_

RECOMMENDATIONS: \_\_\_\_\_

FROM: Virgil Thomas

## Service Dept

---

**Full Name:** Virgil Thomas  
**Last Name:** Thomas  
**First Name:** Virgil  
**Job Title:** Building Inspector  
**Department:** DSI

**Business:** 651-266-9023

**E-mail:** Virgil.Thomas@ci.stpaul.mn.us  
**E-mail Display As:** Virgil Thomas (Virgil.Thomas@ci.stpaul.mn.us)