



APPLICATION FOR APPEAL

RECEIVED
OCT 22 2010
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:
Tuesday, <u>Nov. 2</u>
Time <u>1:30</u>
Location of Hearing:
Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1807 Stillwater Ave E City: St. Paul State: MN Zip: 55109

Appellant/Applicant: Beissel Window and Siding, Co.* Email jeff@beisselwindows.com

Phone Numbers: Business 651-451-6835 Residence _____ Cell _____

Signature: *Jeff W Beissel* Date: 10/20/10

Name of Owner (if other than Appellant): Don and Bev Glaser

Address (if not Appellant's): 2048 East County Rd F, Suite #9 White Bear Lake, MN 55110

Phone Numbers: Business _____ Residence 651-407-3612 Cell _____

What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O see attached
- Summary/Vehicle Abatement Previously approved windows of this exact
- Fire C of O Deficiency List size on appeal:
- Fire C of O: Only Egress Windows 1351 & 1361 Conway St. (identical buildings)
- Code Enforcement Correction Notice 458 & 470 English St
- Vacant Building Registration _____
- Other Bedroom Egress _____
- Other * Beissel Window and Siding, Co.
- Other 1635 Oakdale Avenue, West St. Paul, MN 55118



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: September 30, 2010

APPEAL PROPERTY ADDRESS: 1807 STILLWATER AVE
APPLICANT NAME: BEISSEL WINDOW & SIDING CO
PHONE NUMBER: 651-266-9071
PERMIT NUMBER: 10 903546
TYPE OF WINDOW: Double hung
NUMBER OF WINDOWS: 23

Total Glazed Area	8.26	Difference from Required Area	+3.26
Width of Opening	31	Difference from Required Opening	+11
Height of Opening	18.875	Difference from Required Opening	-5.125
Height of Opening to Finished Floor	35	Difference from Maximum Height	ok

COMMENTS: NA

Reviewed by: Rehn



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: September 30, 2010

APPEAL PROPERTY ADDRESS: 1807 STILLWATER AVE
APPLICANT NAME: BEISSEL WINDOW & SIDING CO
PHONE NUMBER: 651-266-9071
PERMIT NUMBER: 10 903546
TYPE OF WINDOW Double hung
NUMBER OF WINDOWS 22

Total Glazed Area	10.56	Difference from Required Area	+5.56
Width of Opening	36.75	Difference from Required Opening	+16.75
Height of Opening	18.875	Difference from Required Opening	-5.125
Height of Opening to Finished Floor	35	Difference from Maximum Height	ok

COMMENTS: NA

Reviewed by: Rehn