

Saint Paul - Ramsey County Department of Public Health  
Environmental Health Section  
2785 White Bear Avenue North Suite 350  
Maplewood, MN 55109-1320  
FAX: (651) 266-1177

COVER SHEET AND TRANSMISSION FORM

FACSIMILE TRANSMISSION

Date: \_\_\_\_\_  
To FAX#: 6-8574

RECEIVED  
DEC 02 2010  
CITY CLERK

To: Mai Yang, Paralegal

Location: Legislative Hearing Office  
City of St Paul

Sender: Daniel Schmidt / Tim Yamorelly  
St Paul - Ramsey Cty. Dept. of Public Health

This transmission consists of \_\_\_\_\_ pages (including cover sheet).

If transmission is incomplete or illegible, call sender at (651) 266-1173 (DANIEL SCHMIDT)

Message:

*Request for Egress Window Non-Compliance Determination*  
*Attachments: Egress Window Non-Compliance Determination Form*

**CONFIDENTIALITY NOTICE**

The document(s) accompanying this facsimile transmission may contain confidential information intended only for the use of the recipient named above. If you are not the intended recipient, you are hereby notified that any disclosure, copying or distribution of the contents of this transmission except its direct delivery to the intended recipient is strictly prohibited. If you have received this transmission in error, please notify us immediately by telephone to arrange for return of the original message to us.

CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM



**EGRESS WINDOW NON-COMPLIANCE DETERMINATION**

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: \_\_\_\_\_

APPEAL PROPERTY ADDRESS: 914 Conway St #1 & #2  
APPLICANT NAME: ST PAUL & RAMSEY CO PHONE NUMBER: 651-266-1143  
PUBLIC HEALTH BUILDING OWNER (DAVIDEL)


PERMIT NUMBER: \_\_\_\_\_  
TYPE OF WINDOW: DOUBLE HUNG  
NUMBER OF WINDOWS: 2

TOTAL GLAZED AREA: 9.09 sq ft DIFFERENCE FROM REQUIRED AREA: COMPLIES  
WIDTH OF OPENING: 25.2" DIFFERENCE FROM REQUIRED OPENING: COMPLIES  
HEIGHT OF OPENING: 19.9" DIFFERENCE FROM REQUIRED OPENING: 4.1"  
HEIGHT OF OPENING: \_\_\_\_\_ DIFFERENCE FROM REQUIRED OPENING: \_\_\_\_\_  
% FINISHED FLOOR: LESS THAN 48" DIFFERENCE FROM MAXIMUM HEIGHT: COMPLIES

RECOMMENDATION (IF APPLICABLE): SEE EXHIBIT A

(2) windows, (1) in unit #1 and (1) in unit #2

EXHIBIT A



Select a Model

(Model 0201)

Excaltibur Double Hung

Top Sash Width	28.3750
Top Sash Height	25.1250
Bottom Sash Width	27.3750
Bottom Sash Height	25.1250
Top Glass Width	24.8750
Bottom Glass Width	25.8750
Screen Width	26.3750
Top Sash Weight (lbs & lb)	21 lb
Top Balance Size (lb-in)	21.75
Bottom Balance Size (lb-in)	21.75
Screen Opening Width	24.2500
Screen Opening Area (sq. ft.)	3.4920

Exact Size

Width	28.625	28.625
Height	53.375	53.375

Exclusion: Select Exclusion  
 Opening: Exact Size  
 Type: Standard  
 Screen: Full  
 Glass: Double Strength (3 mm)

AC Sash Control

\* 25.93 x 50.5 = 1309.4 ÷ 144 = 9.09 sqft



EGRESS WINDOW NON-COMPLIANCE DETERMINATION

No. 5791 P. 4

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: \_\_\_\_\_

APPEAL PROPERTY ADDRESS: 914 Conway St #1 & #2

APPLICANT NAME: ST. PAUL & RAMSEY CO PUBLIC HEALTH PHONE NUMBER: 266-1143 (DANIELS)

PERMIT NUMBER: \_\_\_\_\_

TYPE OF WINDOW: DOUBLE HUNG

NUMBER OF WINDOWS: 2

TOTAL GLAZED AREA: 8.89 sqft DIFFERENCE FROM REQUIRED AREA: COMPLIES

WIDTH OF OPENING: 23.22 DIFFERENCE FROM REQUIRED OPENING: COMPLIES

HEIGHT OF OPENING: 19.9 DIFFERENCE FROM REQUIRED OPENING: 4.1"

HEIGHT OF OPENING OF FINISHED FLOOR: < 48" DIFFERENCE FROM MAXIMUM HEIGHT: COMPLIES

RECOMMENDATION (IF APPLICABLE): SEE EXHIBIT B

2) windows, (1) in unit #1 and (1) in unit #2

St Paul-Ramsey Co. Public Health

Dec. 2. 2010 10:08AM

12/2/09

FROM: \_\_\_\_\_

EXHIBIT B



Selecta Model

(Model 0201)  
Excibur Double Hung

Top Sash Width	24.1750
Top Sash Height	25.1250
Bottom Sash Width	25.3750
Bottom Sash Height	22.0000
Top Glass Width	22.6875
Bottom Glass Width	21.8375
Bottom Glass Height	21.8375
Screen Width	23.8075
Top Sash Weight (plus s/h)	20 lb
Top Balance Size (Inch)	21.718
Bottom Balance Size (Inch)	R/C
Bottom Balance Size (Ct Ft)	23.2750
Screen Opening Width	23.2750
Screen Opening Height	22.0000
Screen Opening Area (sq. Ft.)	3.2150

Width	27.625	Equal Size
Height	53.375	27.625
		53.375

Excibur Select Extension  
Opening: Equal Size  
Type: Standard  
Screen: Std  
Glass: Double Strength (mm)

No Sash Channel

\* 23.93 x 50.5 = 1208.46 ÷ 144 = 8.39 sq ft