



APPLICATION FOR APPEAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

RECEIVED

JAN 23 2012

CITY CLERK

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR Mail-In

YOUR HEARING Date and Time:

Tuesday, Feb 7, 2012

Time 1:30 P.M.

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1621 Arlington Ave E City: St. Paul State: MN Zip: 55106

Appellant/Applicant: Tony Swanson Email anthony.Swanson@StPHA.org

Phone Numbers: Business 651-298-4907 Residence _____ Cell _____

Signature: Tony Swanson Date: 1-20-12

Name of Owner (if other than Appellant): Public Housing Agency of St. Paul

Address (if not Appellant's): 555 N. Wabasha Suite # 400 St. Paul, MN 55102

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other

#7 MSFC 1026.1 Request
Variance on openable height.

C: K. LYKSETT
B. SHERRY

DEPARTMENT OF SAFETY AND INSPECTIONS
Fire Inspection Division
Ricardo X. Cervantes, Director




CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

January 11, 2012

BETTY LOU AUTHIER
PUBLIC HOUSING AGENCY
200 ARCH ST E
ST PAUL MN 55130-4347



FIRE INSPECTION CORRECTION NOTICE

RE: 1621 ARLINGTON AVE E
Ref. #111213
Residential Class: C

Dear Property Representative:

Your building was inspected on January 11, 2012 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date. A re-inspection will be made on February 13, 2012 at 10:45A.M..

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

- K. LYKSETT - W/O # 6042432 RESIDENT TO BRING TO SHOP.*
1. Storm doors - SPLC 34.09 (3), 34.32 (3) - Provide or repair and maintain the window screen.
 2. *B. SHERRY - PROVIDE DOCUMENTATION TO NANCY*
SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
 3. *N. SCHMIOT*
SPLC 39.02(c) - Complete and sign the provided smoke detector affidavit and return it to this office.

- B. SHERRY - W/O# 6042446*
4. MSFC 605.6 - Provide electrical cover plates to all outlets, switches and junction boxes where missing.
B. SHERRY - W/O# 6042447
 5. SPLC 34.10 (4), 34.33 (3) - Provide a bathroom floor impervious to water. After securing toilet to floor caulk the base.
B. SHERRY - W/O# 6042447
 6. SPLC 34.11, SBC 2902.1, SPLC 34.17, MPC 415.0220 - Repair or replace and maintain the plumbing fixture to an operational condition.-Repair or replace and maintain an approved private toilet. Secure toilet to floor
B. SHERRY - W/O# 6042448
 7. MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.-Double hung windows. Openable height is 21inches . Openable width is 24inches. Glazed is 44inches in height by 21 inches in width.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: james.thomas@ci.stpaul.mn.us or call me at 651-266-8983 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

James Thomas
Fire Inspector

Reference Number 111213