

From: [Clint Zane](#)
To: [Joanna Zimny](#); [Mai Vang](#)
Cc: [Armando@amigoroofing.com](#); [Callie@amigoroofing.com](#); [Yangtrue07@gmail.com](#); [wwhart@gmail.com](#); [Joe Yannarely](#)
Subject: 378 Sims Ave
Date: Thursday, May 30, 2024 3:18:44 PM
Attachments: [image002.png](#)
[image003.png](#)
[image004.png](#)

Joanna / Mai,

Today I walked through with Armando, Callie and True to get a more specific list of remaining items. The interior units are complete except for several minor items. Remaining items to abate the nuisance conditions are as follows:

Interior Units:

- Door closers

Attic/upper unit:

- Repair window in bedroom, guard rail, insulate roof cavities, caulk top of shower and ledge outside of window, tempered glass in broken window on stairway

Basement:

- Patch floor, tuck point foundation walls, guard rail, new door in landing

Exterior:

- Missing window screens
- Storm windows on any window that is not double pane
- Patch stucco front right corner
- Flat roof (rear – includes eyebrow): replace roofing with compliant materials, repair soffit/fascia/siding where missing/damaged.
- Bent chain link fence - repair
- Flat roof (front): replace roofing, repair water damaged soffit/fascia
- Gutters with rain leaders

Crawl space under lower unit kitchen:

- Insulate R-20 min with 10 mil vapor barrier, slats to hold insulation in place, cover access and add small louvre with insect screen

Garage:

- Replace charred roof deck on corner by fire, replace shingles, repair/replace soffit and fascia, repair/replace garage door and opener, remove abandoned burned overhead wires from alley to house (Excel or other qualified service provider), removed or replaced Flat roof (rear): rubber and eyebrow above replace shingle or rubber, repair soffit/fascia, one pc siding.

Plumbing:

- No permit required – no corrections

Mechanical:

- Short list of corrections, contact Aaron Havlicek to see if permit is required: 651-266-9043

Electrical:

- Short list of corrections, this work may already be done, need permit and inspection

Best Regards,



The Most Livable
City in America

Clint Zane
Code Compliance Officer
Building Inspector

Department of Safety and Inspections
375 Jackson Street, Suite 300
Saint Paul, MN 55101

P: 651-266-9029

C: 651-248-3860

Clint.Zane@ci.stpaul.mn.us



Making Saint Paul the Most Livable City in America

DSI's Mission: "To preserve and improve the quality of life in Saint Paul by protecting and promoting public health and safety for all."