



November 22, 2024

MOHAMED IBRAHIM  
1333 THOMAS AVE  
ST PAUL MN 55104-2545

**NOTICE OF CONDEMNATION  
UNFIT FOR HUMAN HABITATION  
ORDER TO VACATE**

RE: 1333 THOMAS AVE  
Ref. # 16712

Dear Property Representative:

Your building was inspected on November 22, 2024.

The building was found to be unsafe, unfit for human habitation, a public nuisance, a hazard to the public welfare or otherwise dangerous to human life. A Condemnation Placard has been posted on the building.

The following deficiency list must be completed or the building vacated by the re-inspection date.

A reinspection will be made on or after December 2, 2024.

**CONDEMNATION OF THE BUILDING REVOKES THE CERTIFICATE OF OCCUPANCY.**

Failure to complete the corrections may result in a criminal citation. The Saint Paul Legislative Code requires that no building be occupied without a Fire Certificate of Occupancy.

**DEFICIENCY LIST**

1. MSFC 604.5 - Discontinue use of extension cords used in lieu of permanent wiring.-

2. SPLC 34.14 (2)(A), 34.34 (5)(A) - Provide an approved electrical service adequate to meet the building's needs. Contact Xcel and have service restored by close of business on October 24, 2024-
3. SPLC 34.09 (4) a, 34.33 (3) a - Repair and maintain the window glass. Windows shall be fully supplied with window panes which are without open cracks or holes.-

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at: [james.thomas@ci.stpaul.mn.us](mailto:james.thomas@ci.stpaul.mn.us) or call me at 651-266-8983 between 7:30 - 9:00 a.m. Please help make Saint Paul a safer place in which to live and work.

Sincerely,

James Thomas  
Fire Safety Inspector  
Ref. # 16712