



CITY OF SAINT PAUL

375 Jackson Street, Suite 220
St Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-9124
Web: www.stpaul.gov/dsi

December 18, 2019

Renters Warehouse
13200 PIONEER TRAIL SUITE 100
EDEN PRAIRIE MN 55347USA

Revocation of Fire Certificate of Occupancy and Order to Vacate

RE: 980 CONWAY ST
Ref. # 107745

Dear Property Representative:

Your building was inspected on December 16, 2019, for the renewal of the Certificate of Occupancy. Since you have failed to comply with the applicable requirements, it has become necessary to revoke the Certificate of Occupancy in accordance with Section 40.06 of the Saint Paul Legislative Code. A reinspection will be made on January 2, 2020 at 11:00a.m. or the property vacated.

The Saint Paul Legislative Code further provides that no building shall be occupied without a Certificate of Occupancy. Failure to immediately complete the following deficiency list or the building vacated may result in a criminal citation.

DEFICIENCY LIST

1. Upstairs - MSFC 603.7 - Immediately cease using the stove or oven for heating.-
2. Upstairs - SPLC 34.11 (6) - Provide and maintain a minimum of 68 degrees F in all habitable rooms at all times.-
3. SPLC 39.02(c) - Complete and sign the smoke detector affidavit and return it to this office.
4. SPLC 34.11 (6), 34.35 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.-

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: james.thomas@ci.stpaul.mn.us or call me at 651-266-8983 between 7:30 - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

James Thomas
Fire Safety Inspector

Ref. # 107745