



CITY OF SAINT PAUL
OFFICE OF THE CITY COUNCIL
310 CITY HALL
15 WEST KELLOGG BOULEVARD
SAINT PAUL, MN 55102-1615
EMAIL: legislativehearings@ci.stpaul.mn.us
PHONE: (651) 266-8560 FAX: (651) 266-8574

December 15, 2010

Dan Parker
Custom Remodelers, Inc.
obo Lenny & Rita Leier
474 Apollo Drive
Lino Lakes MN 55014-0000

VIA EMAIL: judy.h@customremodelersinc.com

Re: Appeal of Window Permit for property at 334 Saratoga Street South
File No. ALH 10-468

Dear Mr. Parker:

This is to confirm that on December 1, 2010 Marcia Moermond, the Legislative Hearing Officer, reviewed the above-referenced appeal and recommended granting a 2-inch variance on the openable height of three double hung replacement egress bedroom windows which measured at 22 inches high by 23 inches wide.

If you have any further questions, you may contact me at 651-266-8563.

Sincerely,

/s/

Mai Vang
Legislative Hearing Coordinator

c: Fire Supervisors (email)
Pat Fish (email)
Jim Bloom (email)
Ryan Rehn (email)
Stephen Ubl (email)
File