



APPLICATION FOR APPEAL

RECEIVED
NOV 01 2010
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:	
Tuesday, <u>Nov. 9</u>	
Time <u>1:30</u>	
Location of Hearing:	
<u>Room 330 City Hall/Courthouse</u>	

Address Being Appealed:

Number & Street: 551 WARWICK STREET City: ST. PAUL State: MN Zip: 55116

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

Signature: [Signature] Date: _____

Name of Owner (if other than Appellant): HOLLY SMART

Address (if not Appellant's): 551 WARWICK ST

Phone Numbers: Business _____ Residence 651-699-0785 Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are appealing 4 double hung replacement windows that do not comply w/ Egress Policies. The current dimensions will be short by 1 1/8" and will exceed minimum opening width by 6".
Please Approve.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: October 26, 2010

APPEAL PROPERTY ADDRESS: 551 WARWICK ST
APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION
PHONE NUMBER: 651-266-9071
PERMIT NUMBER: 10 914577
TYPE OF WINDOW: Double Hung
NUMBER OF WINDOWS: 4

Total Glazed Area	10.9 sq. ft.	Difference from Required Area	+ 5.9 sq. ft.
Width of Opening	26"	Difference from Required Opening	+ 6"
Height of Opening	22 7/8"	Difference from Required Opening	- 1 1/8"
Height of Opening to Finished Floor	NA	Difference from Maximum Height	NA

COMMENTS: Do to information provided above recommend approval.

Reviewed by: B.H.