

RECEIVED

NOV 10 2010



APPLICATION FOR APPEAL CITY CLERK

Saint Paul City Clerk
15 W. Kellogg Blvd., 310 City Hall
Saint Paul, Minnesota 55102
Telephone: (651) 266-8688

1. Address of Property being Appealed: <u>961 Osceola Ave</u>	2. Number of Dwelling Units: <u>1</u>	3. Date of Letter Appealed: <u>11-10-10</u>
--	--	--

4. Name of Owner: Doug + Sara Wolff
 Address: 961 Osceola Ave City: St. Paul State: MN Zip: 55113
 Phone Numbers: Business _____ Residence 651-293-1303 Cellular _____
 Signature: _____

5. Appellant / Applicant (if other than owner): Twin Cities Remodeling Inc.
 Address: 976 Lovell Ave W City: Roseville State: MN Zip: 55113
 Phone Numbers: Business 651-490-0036 Residence _____ Cellular 651-230-2222
 Signature: Dawn Childs (Dawn Childs) Fax 651-490-7876

6 State specifically what is being appealed and why (Use an attachment if necessary):
4 bedroom windows egress code

NOTE: A \$25.00 filing fee made payable to the City of Saint Paul must accompany this application as a necessary condition for filing. You must attach a copy of the original orders and any other correspondence relative to this appeal. Any person unsatisfied by the final decision of the City Council may obtain judicial review by timely filing of an action as provided by law in District Court.

For Office Use Only

Date Received: <u>11-10-10</u>	Fee Received: <u>25.00</u> <u>check 4080</u>	Receipt Number: <u>---</u>	Date of Hearing: <u>November 16, 2010</u> <u>1:30 p.m.</u>
-----------------------------------	--	-------------------------------	--

Suite 330 CLK



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: November 10, 2010

APPEAL PROPERTY ADDRESS: 961 OSCEOLA AVE
APPLICANT NAME: TWIN CITIES REMODELING INC
PHONE NUMBER: 651-266-9071
PERMIT NUMBER: 10 921407
TYPE OF WINDOW: DOUBLE HUNG
NUMBER OF WINDOWS: 4

Total Glazed Area	8 sq.ft	Difference from Required Area	+ 3 sq.ft
Width of Opening	26.07"	Difference from Required Opening	+ 6.07"
Height of Opening	22.34"	Difference from Required Opening	- 1.66"
Height of Opening to Finished Floor	NA	Difference from Maximum Height	NA

COMMENTS: Based on information provided above determination to be made by the legislative hearing officer.

Reviewed by: jps