

Moermond, Marcia (CI-StPaul)

From: Moermond, Marcia (CI-StPaul)
Sent: Tuesday, September 27, 2016 5:36 PM
To: 'stmarie8@comcast.net'
Cc: Ubl, Stephen (CI-StPaul)
Subject: Referral of Your Appeal
Attachments: 1315 Bush Ave.appeal.09-27-16.pdf

Ms. St. Marie,

As per my voicemail I am forwarding your appeal to Saint Paul's Building Official, Steve Ubl. When examining a case where the ceiling for the upper level is 6'10", rather than 7', he will want to consider several factors. These include things like the width of the stairs leading to the upper level, the existence and placement of handrails, presence of smoke alarms and presence of an egress window. This list may not be exhaustive, but I'm hoping it gives you a starting place for information to provide Mr. Ubl. Please email him a request for continued use of this space for sleeping purposes. Photos are very helpful. I note the fire inspector specifically states there are 2 egress windows.

Best Wishes, Marcia Moermond
Legislative Hearing Officer
Saint Paul City Council