



# APPLICATION FOR APPEAL

RECEIVED

JAN 31 2012

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

**The City Clerk needs the following to process your appeal:**

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number \_\_\_\_\_)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

<b>YOUR HEARING Date and Time:</b>	
Tuesday, <u>2-14-12</u>	
Time <u>1:30</u>	
<b>Location of Hearing:</b>	
<u>Room 330 City Hall/Courthouse</u>	

## Address Being Appealed:

Number & Street: 1003 front Ave City: St. Paul State: MN Zip: 55103

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence \_\_\_\_\_ Cell \_\_\_\_\_

Signature: [Signature] Date: 01/23/2012

Name of Owner (if other than Appellant): Wells Thuid

Address (if not Appellant's): 1003 Front Ave

Phone Numbers: Business \_\_\_\_\_ Residence 651-489-2009 Cell \_\_\_\_\_

## What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/
- Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are appealing 3 replacement windows that will not comply w/ egress policy. Window sizes/dimensions are included. Homeowner would like to keep style consistent w/ style throughout the home. Please Approve.



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

## EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: January 23, 2012

APPEAL PROPERTY ADDRESS: 1003 FRONT AVE

APPLICANT NAME: RENEWAL BY ANDERSON CORPORATION

PHONE NUMBER: 651-264-4893

PERMIT NUMBER: 12 009822

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 3

<b>Total Glazed Area</b> Minimum 5 Square Feet	7.0 sq/ft	<b>Difference from Required Area</b>	+2.0 Sq/Ft
<b>Width of Opening</b> Minimum 20 Inches	22"	<b>Difference from Required Opening</b>	+2"
<b>Height of Opening</b> Minimum 24 Inches	23"	<b>Difference from Required Opening</b>	-1"
<b>Height of Opening to Finished Floor</b> Maximum 48 Inches for Existing Openings	<44	<b>Difference from Maximum Height</b>	Ok

COMMENTS: N/A

Reviewed by: J Hoffman 1-23-12