



APPLICATION FOR APPEAL

RECEIVED
DEC 17 2010
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number 517502)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, Jan. 4, 2011

Time 1:30 p.m.

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 815 Iowa Ave W. City: St. Paul State: MN Zip: 55117

Appellant/Applicant: Tracy Anderson/Pella Windows & Doors Email: andersont1@pella.com

Phone Numbers: Business 612-840-8154 Residence 7101 France Ave Edina MN 55435 Cell _____

Signature: [Handwritten Signature] Date: 12/17/10

Name of Owner (if other than Appellant): Jerry Ducloux

Address (if not Appellant's): 815 Iowa Ave W. St. Paul, MN 55117

Phone Numbers: Business _____ Residence 651-409-0469 Cell _____

What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

appealing clear opening height requirement



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: December 1, 2010

APPEAL PROPERTY ADDRESS: 815 IOWA AVE W

APPLICANT NAME: PELLA WINDOWS & DOORS TWIN CITIES INC

PHONE NUMBER: 651-266-9020

PERMIT NUMBER: 10 916810

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 4 windows in 2 bedrooms

Total Glazed Area		Difference from Required Area	
	1.10 sq. ft.		1. +5 sq. ft. ok
	2. 8 sq.ft.		2. +3 sq. ft. ok
	3. 8 sq.ft.		3. +3 sq. ft. ok
	4. 7 sq. ft.		4. + 2 sq.ft. ok

Width of Opening	1. 36" 2. 28" 3. 28" 4. 24"	Difference from Required Opening	1. +16"ok 2. +8"ok 3. +8"ok 4. +4"ok
Height of Opening	1. 21" 2. 21" 3. 21" 4. 21"	Difference from Required Opening	1. -3" 2. -3" 3. -3" 4. -3"
Height of Opening to Finished Floor	1. 28" 2. 28" 3. 28" 4. 28"	Difference from Maximum Height	1. +20"ok 2. +20"ok 3. +20"ok 4. +20"ok

COMMENTS: Windows 1&2 in front bedroom. Windows 3&4 in rear bedroom.

Reviewed by: David Tank