



APPLICATION FOR APPEAL

RECEIVED
FEB 28 2011

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- ☒ \$25 filing fee payable to the City of Saint Paul
(if cash: receipt number _____)
- ☒ Copy of the City-issued orders or letter which
are being appealed
- ☐ Attachments you may wish to include
- ☒ This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 3-15-11

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1342 Grand Ave. City: St. Paul State: MN Zip: 55105
Appellant/Applicant: Aaron Jensen Email: stpaul@greenmill.com
St. Paul Green Mill Restaurant

Phone Numbers: Business 651-678-0553 Residence _____ Cell 651-285-6832

Signature: Aaron Jensen Date: 2-21-11

Name of Owner (if other than Appellant): Paul Dzubnar

Address (if not Appellant's): same as above

Phone Numbers: Business same as above Residence _____ Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- ☐ Vacate Order/Condemnation/
- ☐ Revocation of Fire C of O
- ☐ Summary/Vehicle Abatement
- ☐ Fire C of O Deficiency List
- ☐ Fire C of O: Only Egress Windows
- ☒ Code Enforcement Correction Notice
- ☐ Vacant Building Registration
- ☐ Other
- ☐ Other
- ☐ Other

We do not want to
remove the door that separates
the two restaurants. We
were cleared to have the
door by permit for the
Twisted Fork Grille remodel.



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

February 17, 2011

GREEN MILL
1340 GRAND AVE
ST PAUL MN 55105

FIRE INSPECTION CORRECTION NOTICE

RE: 1342 GRAND AVE
Ref. #11554

Dear Property Representative:

Your building was inspected on November 8, 2010 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date. **A re-inspection will be made after April 18, 2011.**

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

1. FIRE ALARM SYSTEM - MSFC 907.3 - Provide an approved fire alarm system. This work may require a permit(s), call DSI at (651) 266-9090.
2. KEYBOX - MSFC 506.1 - Install a keybox.-Required for fire alarm system.
3. TWISTED FORK - MSFC 1005.2 - Provide an approved additional means of egress due to an inadequate number of exits.-Remove door from the back of Twisted Fork. When Twisted Fork is not open a rope may be used across the door to limit entry.
4. TWISTED FORK - MSFC 1010.3 - Provide and maintain approved external or internal lighting of the exit sign.-Provide exit sign on second exit.

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102. Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: **Kris.Skow-Fiske@ci.stpaul.mn.us** or call me at 651-266-8949 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Kris Skow-Fiske
Fire Inspector

Reference Number 11554