



APPLICATION FOR APPEAL

Saint Paul City Clerk
15 W. Kellogg Blvd., 310 City Hall
Saint Paul, Minnesota 55102
Telephone: (651) 266-8688

RECEIVED
JAN 12 2011
CITY CLERK

RECEIVED
JAN 12 2011
CITY CLERK

WALKIN

1. Address of Property being Appealed: <u>2226 Upper Afton Rd.</u>	2. Number of Dwelling Units:	3. Date of Letter Appealed:
---	------------------------------	-----------------------------

4. Name of Owner: Jennifer Reisdorph
 Address: 2226 Upper Afton Rd. City: St. Paul State: MN Zip: _____
 Phone Numbers: Business _____ Residence: (651) 731-5826 Cellular _____
 Signature: [Signature]

5. Appellant / Applicant (if other than owner): Woodcrest Bldg. Remodely (Erik Anderson)
 Address: 2809 Woodcrest Drive City: Mounds View State: MN Zip: 55112
 Phone Numbers: Business 651-246-9457 Residence _____ Cellular _____
 Signature: [Signature]

6 State specifically what is being appealed and why (Use an attachment if necessary):

We installed Vinyl insert Windows for Jennifer. The existing size of the window frames and the window manufacturer only allowed us to install double hung windows which do not meet the 24" clear opening height.

NOTE: A \$25.00 filing fee made payable to the City of Saint Paul must accompany this application as a necessary condition for filing. You must attach a copy of the original orders and any other correspondence relative to this appeal. Any person unsatisfied by the final decision of the City Council may obtain judicial review by timely filing of an action as provided by law in District Court.

For Office Use Only			
Date Received: <u>1/13/11</u>	Fee Received: <u>25p</u>	Receipt Number:	Date of Hearing: <u>1-18-11 1:30 p.m.</u>



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: January 4, 2011

APPEAL PROPERTY ADDRESS: 2226 UPPER AFTON ROAD

APPLICANT NAME: WOODCREST BUILDING & REMODELING INC

PHONE NUMBER: 651-266-9071

PERMIT NUMBER: 11 002335

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 3

Total Glazed Area Minimum 5 Square Feet	9.0 sq. ft.	Difference from Required Area	+ 4 sq. ft.
Width of Opening Minimum 20 Inches	37.5"	Difference from Required Opening	+ 17.5"
Height of Opening Minimum 24 Inches	16.5"	Difference from Required Opening	- 7.5"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	NA	Difference from Maximum Height	NA

COMMENTS:

Reviewed by: B. H.

