



# APPLICATION FOR APPEAL

**Saint Paul City Clerk**

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

RECEIVED

MAR 16 2012

CITY CLERK

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number \_\_\_\_\_)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

**YOUR HEARING Date and Time:**

Tuesday, 3-27-12

Time 1:30 P.M.

Location of Hearing:

Room 330 City Hall/Courthouse

## Address Being Appealed:

Number & Street: 1085 Case Ave So City: Saint Paul State: MN Zip: 55106

Appellant/Applicant: Window Concepts (JoAnne) Email: joanne.burr@windowconceptsminn.com

Phone Numbers: Business 651 604 8266 Residence \_\_\_\_\_ Cell @ 651-497 5881

Signature: JoAnne Burr Date: 3/14/12

Name of Owner (if other than Appellant): Cathy Azimian

Address (if not Appellant's): 1085 Case Ave So.

Phone Numbers: Business \_\_\_\_\_ Residence 651 774 3286 Cell \_\_\_\_\_

## What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

State code states that all windows that are replaced with the same size & style are grandfathered in & meet code



CITY OF SAINT PAUL  
 INTERDEPARTMENTAL MEMORANDUM

**EGRESS WINDOW NON-COMPLIANCE DETERMINATION**

TO: CITY CLERK  
 15 KELLOGG BLVD. WEST  
 310 CITY HALL  
 SAINT PAUL, MN 55102

PHONE: 651-266-8688  
 FAX: 651-266-8574

DATE: February 24, 2012

APPEAL PROPERTY ADDRESS: 1085 CASE AVE

APPLICANT NAME: WINDOW CONCEPTS OF MINNESOTA INC

PHONE NUMBER: 952-883-0476

PERMIT NUMBER: 10 502425

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS Two

Total Glazed Area Minimum 5 Square Feet	6.7 sq. ft.	Difference from Required Area	+1.0 sq. ft.
Width of Opening Minimum 20 Inches	20"	Difference from Required Opening	OK

<b>Height of Opening</b> Minimum 24 Inches	23"	<b>Difference from Required Opening</b>	-1"
<b>Height of Opening to Finished Floor</b> Maximum 48 Inches for Existing Openings	OK Both  Windows	<b>Difference from Maximum Height</b>	

COMMENTS:

Reviewed by: David Nelson