



City of Saint Paul

City Hall and Court
House
15 West Kellogg
Boulevard
Phone: 651-266-8560

Signature Copy

Resolution: RES 18-1701

File Number: RES 18-1701

Pertaining to an ordinance amending Chapter 94 of the Legislative Code of the City of Saint Paul regarding meters, settings, and cable installation.

WHEREAS, Board of Water Commissioners of the City of Saint Paul recommends that Chapter 94 of the Saint Paul Legislative Code of the City of Saint Paul be amended to require the use of type K copper or lead-free brass within the meter setting and at least one foot of its vertical riser; and

WHEREAS, Board's staff has prepared a City of Saint Paul Ordinance, which provides such amendment, copy of said Ordinance being attached hereto; and

WHEREAS, the assistant city attorney has reviewed and approved said Ordinance as to form, and Saint Paul Regional Water Services General Manager recommends approval of said Ordinance; now, therefore, be it

RESOLVED, that the Board of Water Commissioners of the City of Saint Paul does hereby approve the attached Ordinance amending Chapter 94 of the Saint Paul Legislative Code; and, be it

FURTHER RESOLVED, that the Board of Water Commissioners does hereby request that the Honorable Council of the City of Saint Paul approve and adopt said Ordinance.

At a meeting of the Board of Water Commissioners on 10/9/2018, this Resolution was Adopted.

Yea: 5 Chair Anfang, Commissioner Tolbert, Commissioner Rossbach,
Commissioner Noecker, and Commissioner Humphrey

Nay: 0

Absent: 2 Vice Chair Brendmoen, and Commissioner Dains

Board Secretary

Date

10/9/18