

CITY OF SAINT PAUL Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220 Saint Paul, Minnesota 55101-1806
 Telephone:
 651-266-8989

 Facsimile:
 651-266-8951

 Web:
 www.stpaul.gov/dsi

September 14, 2010

DENISE M ELLIOTT 1091 HEATHER DR WOODBURY MN 55129-8573 RE: RE-INSPECTION FIRE CERTIFICATE OF OCCUPANCY WITH DEFICIENCIES 1266 BAYARD AVE

Ref. # 111062

Dear Property Representative:

Your building was re-inspected for the Fire Certificate of Occupancy on August 9, 2010. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected immediately. A reinspection will be made on October 7, 2010 at 9:30 AM.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional reinspection fees.

DEFICIENCY LIST

- 1. Basement steps SPLC 34.10 (3) 34.33(2) Provide an approved guardrail. Intermediate ballustrade must not be more than 4 inches apart. Intermediate rails must be provided if the height of the platform is more than 30 inches.
- Bedrooms MSFC1026.1 Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)-266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information. <u>Southwest</u>
 20 h x 28 w glazed 7.4 sq ft
 <u>Southeast</u>
 20.5 h x 27 w glazed 6.8 sq ft
- 3. Exit doors SPLC 34.09 (3) i Provide and maintain an approved one-inch throw single cylinder deadbolt lock.

- 4. Exterior SPLC 34.09 (3), 34.32 (3) Repair and maintain the window frame.-Scrape and remove chipped and peeling paint. Repaint in a professional manner.
- 5. Exterior SPLC 34.08 (3) Provide and maintain suitable ground cover on all exterior areas to control erosion.
- 6. Front door Frame and threshold SPLC 34.09 (3), 34.32 (3) Repair and maintain the door frame.-Scrape and remove chipped and peeling paint. Repaint in a professional manner.
- 7. Garage SPLC 34.08 (5), 34.31 (3) Repair, replace and maintain all exterior surfaces on fences, sheds, garages and other accessory structures free from holes and deterioration. Provide and maintain exterior unprotected surfaces painted or protected from the elements.-Scrape and remove chipped and peeling paint. Repaint in a professional manner.
- 8. Garage SPLC 34.08 (5), 34.31 (3) Repair, replace and maintain all exterior surfaces on fences, sheds, garages and other accessory structures free from holes and deterioration. Provide and maintain exterior unprotected surfaces painted or protected from the elements.-Repair or replace damaged and deteriorated siding.
- 9. Garage SPLC 71.01 The address posted is not visible from street. (HN-1)-Provide reflective numbers that face the alley.
- 10. Southwest bedroom SPLC 34.09 (3), 34.32 (3) Repair and maintain the door latch.-Provide approved handle for crawl space door.
- 11. Throughout MSFC 605.5 Discontinue use of extension cords used in lieu of permanent wiring.
- 12. SPLC 34.11 (6), 34.34 (3) Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
- 13. SPLC 39.02(c) Complete and sign the provided smoke detector affidavit and return it to this office.

For an explanation or information on some of the violations contained in this report, please visit our web page at: http://www.ci.stpaul.mn.us/index.aspx?NID=211

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at rick.gavin@ci.stpaul.mn.us or call me at 651-266-8994 between 7:30 a.m - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Rick Gavin Fire Inspector Ref. # 111062