



APPLICATION FOR APPEAL

OCT 20 2010

Saint Paul City Clerk

CITY CLERK

10 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- ☒ \$25 filing fee payable to the City of Saint Paul
(if cash: receipt number _____)
- ☒ Copy of the City-issued orders or letter which
are being appealed
- ☐ Attachments you may wish to include
- ☒ This appeal form completed

YOUR HEARING Date and Time:

Tuesday, Oct. 26

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1139 Norbert Lane City: ST Paul State: MN Zip: 55116

Appellant/Applicant: Jim McCorkle Email: Jim@Admissionpossible.org

Phone Numbers: Business 651-917-3525 Residence 651-336-5278 Cell _____

Signature: J. McCorkle Date: 10/19/10

Name of Owner (if other than Appellant): _____


Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- ☐ Vacate Order/Condemnation/
Revocation of Fire C of O
- ☐ Summary/Vehicle Abatement
- ☒ Fire C of O Deficiency List
- ☐ Fire C of O: Only Egress Windows
- ☐ Code Enforcement Correction Notice
- ☐ Vacant Building Registration
- ☐ Other
- ☐ Other
- ☐ Other

I'm appealing item #3 related
to the size of bedroom windows.
These are now large windows that
would allow fire escape and/or
fire fighters to enter.
The inspector lists the window
dimensions.



ADMISSION POSSIBLE

Jim McCorkell

Chief Executive Officer

Phone 651.917.3525

Fax 651.917.3522

JimMcCorkell@AdmissionPossible.org

450 N. Syndicate Street, Ste. 200

St. Paul, MN 55104

www.AdmissionPossible.org



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

October 14, 2010

JAMES MCCORKELL
1503 GOODRICH AVE
ST PAUL MN 55105-2319

FIRE INSPECTION CORRECTION NOTICE

RE: 1139 NORBERT LANE
Ref. #104702
Residential Class: B

Dear Property Representative:

Your building was inspected on October 14, 2010 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date. A re-inspection will be made on November 18, 2010 at 11:30 AM.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

1. Basement - 1141 - NFPA 211,9-2 - Have the chimneys, fireplaces, and vents inspected for soundness, freedom from deposits, and correct clearances. Cleaning, maintenance, and repairs shall be done if indicated by the inspection.
2. Basement - MSFC 605.1 - Repair or replace damaged electrical fixtures. This work may require a permit(s). Call DSI at (651) 266-9090.

3. Bedrooms throughout - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.-

1139

20.5 h x 36 w Glazed 11.3 sq ft

1141

20.5 h x 36 w Glazed 11.3 sq ft

4. Throughout - NEC 440.13 - For cord-connected equipment such as room air conditioners, household refrigerators and freezers, drinking water coolers, and beverage dispensers, a separable connector or an attachment plug and receptacle shall be permitted to serve as the disconnecting means. The appliance must plug directly into a permanent outlet.-Kitchen of both units. Washing machine plugged in with extension cord.
5. SPLC 34.09 (3) - Provide and maintain an approved one-inch throw single cylinder deadbolt lock on exit doors.

For an explanation or information on some of the violations contained in this report, please visit our web page at: <http://www.ci.stpaul.mn.us/index.aspx?NID=211>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: rick.gavin@ci.stpaul.mn.us or call me at 651-266-8994 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Rick Gavin
Fire Inspector

Reference Number 104702