

# APPLICATION FOR APPEAL

# Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd. Saint Paul, Minnesota 55102 Telephone: (651) 266-8560

# RECEIVED MOV 3 0 2010

MOA	3 0 2010	
\$25 filing fee payable to the City of the City of the City of the City-issued orders or less are being appealed  Attachments you may wish to include the City of the City-issued orders or less are being appealed  This appeal form completed	Saint Paul tter which	YOUR HEARING Date and Time:  Tuesday, 12/14/10  Time
Address Being Appealed:		
Number & Street: 35/ Law	1500 Ave. E. City: S.	+ Paul State: MN. Zip: 55130
Appellant/Applicant: Sergio Rodr.	ignez Em	nail rdzauto 411 a hot mailion
4		6-8026 Cell 651-260-7704
Signature:		Date: 11-30-10
Name of Owner (if other than Appellant):		
Address (if not Appellant's):		
Phone Numbers: Business	Residence	Cell
What Is Being appeale  Vacate Order/Condemnation/ Revocation of Fire C of O	•	Attachments Are Acceptable
□ Summary/Vehicle Abatement	Windows Must be	Min. 5 square ft. ghzed area twit
☐ Fire C of O Deficiency List ☐ Fire C of O: Only Egress Windows	min. 24" apenable,	ht + 20" apenable width.
□ Code Enforcement Correction Notice	our double Hono w	indois masured 19" operable ht.
□ Vacant Building Registration	* 26" openable	
□ Other	Appeal - because	- New windows and the width
□ Other	is bigger than the	e ht, required, and the bedrooms
□ Other		2nd bed rooms that have require



CITY OF SAINT PAUL Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220 Saint Paul, Minnesota 55101-1806 Telephone: 651-266-8989 Facsimile: 651-266-8951 Web: www.stpaul.gov/dsi

November 23, 2010

SERGIO RODRIGUEZ 358 LAWSON AVE E ST PAUL MN 55130-3930

#### FIRE INSPECTION CORRECTION NOTICE

RE:

351 LAWSON AVE E

Ref. #104905 Residential Class: C

### Dear Property Representative:

Your building was inspected on November 23, 2010 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date.

## A re-inspection will be made on December 27, 2010 at 10:15 am.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

### **DEFICIENCY LIST**

- 1. EXTERIOR SPLC 34.09 (2), 34.32(2) Repair or replace the unsafe stairways, porch, decks or railings in an approved manner. This work may require a permit(s). Call DSI at (651) 266-9090.- Repair broken front concrete steps in a professional manner.
- 2. EXTERIOR SPLC 34.08 (5), 34.31 (3) Repair, replace and maintain all exterior surfaces on fences, sheds, garages and other accessory structures free from holes and deterioration. Provide and maintain exterior unprotected surfaces painted or protected from the elements.-Scrape and paint front door frame and front porch deck and rails in a professional manner.
- 3. EXTERIOR SPLC 34.09 (1) e, 34.32 (1) d Provide and maintained the roof weather tight and free from defects.-Repair holes in eaves on east side of house in a professional manner.
- 4. EXTERIOR SPLC 71.01 Provide address numbers on building per attached HN-1 handout.-Provide rear address numbers that are clearly visible from the alley.

- 5. EXTERIOR SPLC 34.09 (3), 34.32 (3) Repair and maintain the door in good condition.-Replace door closer on rear storm door.
- 6. INTERIOR BOTH UNITS SPLC 34.09 (3) i Provide and maintain an approved one-inch throw single cylinder deadbolt lock.-Provide deadbolt locks for all unit doors.
- 7. INTERIOR BOTH UNITS MSFC1026.1 Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupanices handout for more information.-Upon inspection, double-hung windows in west bedrooms of Unit 1 and Unit 2 measured 19 inches openable height x 26 inches openable width.
- 8. INTERIOR UNIT 2 MSFC 605.1- All light fixtures shall be maintained with protective globes if originally equipped.
- 9. INTERIOR UNIT 2 SPLC 34.10 (7), 34.33 (6) Repair or replace and maintain the woodwork in an approved manner.-Replace trim around windows in south and west bedrooms in a professional manner.
- 10. INTERIOR UNIT 2 SPLC 34.10 (4), 34.33 (3) Provide a bathroom floor impervious to water.-Replace trim around bathtub and repair damaged wall by bathtub in a professional manner.
- 11. INTERIOR SPLC 34.10 (3), 34.33(2) Provide an approved handrail. The top of the handrail must be between 34 and 38 inches above the treads and run the entire length of the stair.-Provide handrail for basement stairs.

For an explanation or information on some of the violations contained in this report, please visit our web page at: http://www.ci.stpaul.mn.us/index.aspx?NID=211

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: kelly.booker@ci.stpaul.mn.us or call me at 651-266-8985 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Kelly Booker Fire Inspector

Reference Number 104905