

□ Other

The City Clerk needs the following to process your appeal:

APPLICATION FOR APPEAL

DEC 1 4 2010 CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd. Saint Paul, Minnesota 55102 Telephone: (651) 266-8560

YOUR HEARING Date and Time:

| \$25 filing fee payable to the City of Saint Paul (if cash: receipt number) | Tuesday, 12/21/10 |
|---|---|
| Copy of the City-issued orders or letter which | • • • • • • • • • • • • • • • • • • • |
| are being appealed | Time |
| Attachments you may wish to include | Location of Hearing: |
| This appeal form completed | Room 330 City Hall/Courthouse |
| | walk-in |
| Address Being Appealed: | |
| Number & Street: 931 MARION | City: ST Park State: Mr Zip: 65 |
| Appellant/Applicant: JAmes SwArTwood | Email |
| Phone Numbers: Business 6/2.822-79/0 Residence | e 612.822-7810 Cell |
| Signature: | Date: 12/14/2610 |
| Name of Owner (if other than Appellant): | |
| Address (if not Appellant's): 6537 Dyo | NT DS My/5 66419 |
| Phone Numbers: Business Residence | e Cell |
| What Is Being appealed and w | hy? Attachments Are Acceptable |
| /Vacate Order/Condemnation/ | HAVE BEEN MADE B. TOR MISSED SHUT OFF ON STOVE T DONE OF WATER HEATER |
| Vacate Order/Condemnation/ Revocation of Fire C of O | TOR MISSED SHUT OFF ON STOVE |
| □ Summary/Vehicle Abatement | T have ar WATER HEATER |
| Fire C of O Deficiency List | Works Fine |
| ☐ Fire C of O: Only Egress Windows | |
| Code Enforcement Correction Notice | |
| □ Vacant Building Registration | |
| □ Other | |
| □ Other | |



CITY OF SAINT PAUL Christopher B. Coleman, Mayor 375 Jackson Street, Suite 220 Saint Paul, Minnesota 55101-1806

 Telephone:
 651-266-8989

 Facsimile:
 651-266-8951

 Web:
 www.stpaul.gov/dsi

December 6, 2010

JAMES SWARTWOOD 5537 DUPONT AVE S MINNEAPOLIS MN 55419-1647

Revocation of Fire Certificate of Occupancy and Order to Vacate

RE: 931 MARION ST

Dear Property Representative:

Your building was inspected on December 6, 2010, for the renewal of the Certificate of Occupancy. Since you have failed to comply with the applicable requirements, it has become necessary to revoke the Certificate of Occupancy in accordance with Section 33.05 of the Saint Paul Legislative Code.

A re-inspection will be made on December 29, 2010 at 11 am or the property vacated.

The Saint Paul Legislative Code further provides that no building shall be occupied without a Certificate of Occupancy. Failure to immediately complete the following deficiency list or the building vacated may result in a criminal citation.

DEFICIENCY LIST

- 1. Basement SPLC 34.09 (2), 34.32(2) Repair or replace the damaged guardrail in an approved manner. This work may require a permit(s). Call DSI at (651) 266-9090.
- 2. Exterior SPLC 34.09 (3), 34.32 (3) Repair and maintain the door in good condition.
- 3. Exterior SPLC 34.09 (3), 34.32 (3) Repair and maintain the window frame.
- 4. Exterior SPLC 34.09 (3), 34.32 (3) Provide or repair and maintain the window screen.
- 5. Exterior SPLC 34.08 (5), 34.31 (3) Repair, replace and maintain all exterior surfaces on fences, sheds, garages and other accessory structures free from holes and deterioration. Provide and maintain exterior unprotected surfaces painted or protected from the elements.-Provide a report from a licensed structural engineer that the garage is sound. The garage is leaning and the foundation and doors are in poor condition. Repair or remove under permit.

- 6. Exterior SPLC 34.08 (1), 34.31 (1) All exterior property areas shall be maintained free from any accumulation of refuse, garbage or feces.
- 7. Exterior SPLC 34.09 (3), 34.32 (3) Repair and maintain the window glass.-Repair the front broken window on the second floor.
- 8. Interior SPLC 34.19 Provide access to the inspector to all areas of the building.
- 9. Interior SPLC 34.10 (6), 34.33 (5) Exterminate and control insects, rodents or other pests. Provide documentation of extermination.-Hire a licensed exterminator to eliminate mice.
- 10. Interior throughout MSFC 605.1- All light fixtures shall be maintained with protective globes if originally equipped.-Provide globe covers and bulbs on all fixtures.
- 11. Interior throughout MN Stat. 299F.362 Immediately provide and maintain a smoke detector located outside each sleeping area.-Replace the batteries in all smoke detectors. (Beeping)
- 12. Interior throughout SPLC 34.11(5), 34.34(2), SPC 4715.0200Q Provide adequate hot water between 120 degrees F and 130 degrees F.
- 13. Kitchen MFGC 409.5 Provide an approved gas shut off valve within 6 feet of the appliance in accordance with the mechanical code. This work may require a permit(s). Call DSI at (651) 266-8989.
- 14. SPLC 34.11 (6), 34.34 (3) Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
- 15. SPLC 39.02(c) Complete and sign the provided smoke detector affidavit and return it to this office.

For an explanation or information on some of the violations contained in this report, please visit our web page at: http://www.ci.stpaul.mn.us/index.aspx?NID=211

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: lisa.martin@ci.stpaul.mn.us or call me at 651-266-8988 between 6:30 - 8:30 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Lisa Martin Fire Inspector