

(if cash: receipt number_

APPLICATION FOR APPEAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd. Saint Paul, Minnesota 55102 Telephone: (651) 266-8560

YOUR HEARING Date and Time:

Tuesday, 2-15-11

FEB 08 2011

CITY CLERK

The City Clerk needs the following to process your appeal:

\$25 filing fee payable to the City of Saint Paul

Copy of the City-issued orders or letter which

√ are being appealed	Time
Attachments you may wish to include	Location of Hearing:
This appeal form completed	Room 330 City Hall/Courthouse
	mail 2-8-11
Address Being Appeale	d:
Number & Street: 882 Tusca	rora Au City: St. Paul State: MV Zip: 55102
Appellant/Applicant: XoY M	EIXELL Email REMEIXELLEEGANCO, Con
Phone Numbers: Business 763 595 43	10 Residence 651-699-5938Cell 612-270-1107
Signature: Con EM	Date: 2-4-2011
Name of Owner (if other than Appellant): _	LYNN MEIXELL
Address (if not Appellant's): 1574	MISSISSIPPI RIVER BLUD
Phone Numbers: Business 744-2022	Residence 657-699-5938 Cell 612-68-2943
What Is Being appealed	and why? Attachments Are Acceptable
Vacate Order/Condemnation/ Revocation of Fire C of O	
□ Summary/Vehicle Abatement	
□ Fire C of O Deficiency List	
☐ Fire C of O: Only Egress Windows	·
✓ Code Enforcement Correction Notice	SEE POIES
□ Vacant Building Registration	
Other	
- Other	
Other ·	
L Uniti	



CITY OF SAINT PAUL Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220 Saint Paul, Minnesota 55101-1806
 Telephone:
 651-266-8989

 Facsimile:
 651-266-8951

 Web:
 www.stpaul.gov/dsi

January 26, 2011

LYNN MEIXELL 1574 MISSISSIPPI RIVER BLVD S ST PAUL MN 55116-1851

FIRE INSPECTION CORRECTION NOTICE

RE:

882 TUSCARORA AVE

Residential Class: C

Dear Property Representative:

Your building was inspected on January 26, 2011 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date. A reinspection will be made on February 25, 2011 at 9:45 AM.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional reinspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

- 1. Back door SPLC 34.09 (3) i Provide and maintain an approved one-inch throw single cylinder deadbolt lock. NOT CITED ON PREVIOUS IN SPECTIONS 3 DENOROUS IN STALLED BY LICENSED LOCKSMITH.
- 2. Basement MSFC 3404.3.4, SPLC 34.15 (1) Reduce and maintain the flammable or combustible liquids storage quantity in accordance with MSFC 2703.1.1(1) or other approved storage methods.-Immediately discontinue storage of gas inside dwelling. Remove gas can from the basement.
- 3. Basement SPLC 34.10 (5), 34.33 (4), 34.16 Provide and maintain interior in a clean and sanitary condition.-Reomove unused appliances. TEMPORALY UNUSED REPUGENTAN UNPULLED TO SAFE ENERGY

An Equal Opportunity Employer

- 4. Bathroom door SPLC 34.09 (3), 34.32 (3) Repair and maintain the door in good condition.
- 5. Kitchen stove MFGC 409.5 Provide an approved gas shut off valve within 6 feet of the appliance in accordance with the mechanical code. This work may require a permit(s). Call DSI at (651) 266-8989. Not are on the provided in Spectrops.
- 6. Throughout MSFC 901.6 Provide required annual maintenance of the fire extinguishers by a qualified person and tag the fire extinguishers with the date of service.
- 7. Throughout MN State Statute 299F.50 Immediately provide and maintain an approved Carbon Monoxide Alarm in a location within ten (10) feet of each sleeping area. Installation shall be in accordance with manufacturers instructions.
- 8. Throughout MN Stat. 299F.362 Immediately provide and maintain a smoke detector located outside each sleeping area.
- 9. Toilet seat SPLC 34.12 (2), 34.35 (1) Repair and maintain all required and supplied equipment in an operative and safe condition.
- 10. SPLC 39.02(c) Complete and sign the provided smoke detector affidavit and return it to this office.
- 11. NEC 110-26 Provide and maintain a minimum of 36 inches clearance in front of all electrical panels.

For an explanation or information on some of the violations contained in this report, please visit our web page at: http://www.ci.stpaul.mn.us/index.aspx?NID=211

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: rick.gavin@ci.stpaul.mn.us or call me at 651-266-8994 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Rick Gavin Fire Inspector



SERVICE CALL

LOCKSMITH: COMMENTS:

Signature: _

DATE: 7-2-01

LABOR TOTAL

PARTS TOTAL

SALES TAX
GRAND TOTAL

#