## DEPARTMENT OF SAFETY & INSPECTIONS (DSI) ANGIE WIESE, PE(MN), CBO, DIRECTOR



375 Jackson Street, Suite 220 Saint Paul, MN 55101-1806 Tel: 651-266-8989 | Fax: 651-266-9124

March 22, 2023

JIM BERN COMPANY 8162 BLOOMINGTON AVE S BLOOMINGTON MN 55425

RE: RE-INSPECTION FIRE CERTIFICATE OF OCCUPANCY WITH DEFICIENCIES 2234 GLENRIDGE AVE

Ref. # 107397

Dear Property Representative:

Your building was re-inspected for the Fire Certificate of Occupancy on March 22, 2023. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected immediately. A reinspection will be made on April 3, 2023 at 9:15AM.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional reinspection fees.

## DEFICIENCY LIST

- 1. 2236 Bedroom S.E. Side MSFC 1030.1 Provide and maintain an approved escape window from each sleeping room or area, or discontinue use of area as a sleeping room. This work may require permit(s). Call DSI at (651) 266-8989.-One window in every room usd for sleeping purposes requires one window for emergency escape and rescue without any obstructions.
- 2. 2236 MMC 504.1 Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter and installed in accordance with the mechanical code. This work SHALL require a permit(s). Call DSI at (651) 266-8989.-
- 3. 2236 SPLC 34.23, MSFC 111.1 This occupancy is condemned as unsafe or dangerous. This occupancy must not be used until re-inspected and approved by this office.-

- 4. Basement and through the house 2236 MN Stat 299F.18 Immediately remove and discontinue excessive accumulation of combustible materials.-Reduce basement 80% Reduce through out house 75%
- 5. MSFC 315.3.3 Remove combustible storage within 36 inches of fuel burning equipment.-
- 6. MSFC 603.5.3 Provide clearance around all mechanical equipment.-

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: http://www.stpaul.gov/cofo

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at james.thomas@ci.stpaul.mn.us or call me at 651-266-8983 between 7:30 a.m - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

James Thomas Fire Safety Inspector Ref. # 107397