



**CITY OF SAINT PAUL**  
OFFICE OF THE CITY COUNCIL  
310 CITY HALL  
15 WEST KELLOGG BOULEVARD  
SAINT PAUL, MN 55102-1615  
Marcia Moermond, Legislative Hearing Officer  
EMAIL: [legislativehearings@ci.stpaul.mn.us](mailto:legislativehearings@ci.stpaul.mn.us)  
PHONE: (651) 266-8585 FAX: (651) 266-8574

May 18, 2023

Albert Schuna  
1344 Schletti Street  
St. Paul, MN 55117

VIA MAIL

Re: Appeal for Property at 1344 Schletti Street

Dear Albert Schuna:

This is to confirm that at the Legislative Hearing on May 16, 2023, Legislative Hearing Officer Marcia Moermond recommended that the City Council **grant your appeal on condition that the requirements of 1995 permit continue to be met:**

- 1. No combustible/flammable liquids or gasses will be allowed in garage at any time;**
- 2. No combustible/flammable liquid or gas-powered equipment will be allowed in garage at any time; and**
- 3. Owner shall provide (minimum) a 2A-10BC Fire Extinguisher**

This matter will go before the City Council at Public Hearing on **Wednesday, June 7, 2023 at 3:30 pm. in room 300 City Hall.** If you are contesting Ms. Moermond's recommendation from the May 16 hearing you may:

- appear in person (please arrive before 3:30 p.m. and check in with staff outside Council chambers)
- send written testimony to be added to the record to [legislativehearings@ci.stpaul.mn.us](mailto:legislativehearings@ci.stpaul.mn.us) or by voicemail at 651-266-6805.
- **Should you wish to address Council directly but not appear in person, you must register in person by noon on Tuesday, June 6, 2023 here to testify via phone:** <https://www.stpaul.gov/department/city-council/city-council-public-hearing-live-testimony>.

If you don't wish to contest then no further action is needed and the Council will proceed with Ms. Moermond's recommendation above. If you have any questions, please contact me at 651-266-8585.

Sincerely,  
/s/



Joanna Zimny  
Legislative Hearing Executive Assistant

c:

Fire Supervisors  
Hector Caballero – Department of Safety & Inspections, Fire Inspector