



City of Saint Paul
Building Inspection

Building Inspector's

Correction **NOTICE**

Location 733 Fairview Ave. N.

Date 7-17-17

The Inspector was ~~not~~ able to gain entrance into this building on this date for the purpose of inspecting

Please call 266-9046 between 7:30 and 9:00 a.m. to notify inspector when inspection can be made. If we have not received a reply within 30 days of the above date, we will close out the permit with the notation that the quality of work cannot be certified. Any future interested parties making inquiries of this Office will be informed that the work done under permit was not approved.

Jim S
Inspector



No entry to 1st floor

City of Saint Paul
Building Inspection

Inspector's

NOTICE

Location Basement 733 Parkview

Date 2-5-18

The Inspector was unable to gain entrance into this building on this date for the purpose of inspecting

OK To Rock

Please call 266- _____ between 7:30 and 9:00 a.m. to notify inspector when inspection can be made. If we have not received a reply within 30 days of the above date, we will close out the permit with the notation that the quality of work cannot be certified. Any future interested parties making inquiries of this Office will be informed that the work done under permit was not approved.

1. Basement studs overent
at least bedroom.
2. ~~Missing~~ drywall backer
at many areas.
3. Top basement step not
sized properly.
4. 1st. floor bath room wall
framing not done.

CITY OF SAINT PAUL
DEPARTMENT OF SAFETY AND INSPECTIONS

NOTICE

The roughing in of the:

- ELECTRICAL WIRING
- GAS PIPING
- PLUMBING
- HEATING
- HOT WATER PIPING
- STEAM PIPING
- REFRIGERATION PIPING
- SHEET METAL
- WARM AIR HEATING - VENTILATION

in this Building has been inspected and approved and may be closed in or concealed.

Permit No. GAS 2016 10 1171

Location 733 Fairview Ave.

Date 10/12/17

Note: RT gas test approved
50PSI over 24 Hours - no
appliances are installed.

Inspector can not
651-266-8989 turn

Christi
651-266-9045 gas on
until is
appliance is
installed + vented