

are being appealed

APPLICATION FOR APPEAL

HECEIVED

APR 1 2 2011

CITY CLERK

Saint Paul City Clerk

310 City Hall, 13 W. Kellogg Blvd. Saint Páu : Minnesota 55102 Telephone: (651) 266-8560

YOUR HEARING Dute and Time:

Tuesday, April 9, 2011

Time 300

walkin

Revised 8/20/2010

Room 330 City Hall/Courthouse

Attachments you may wish to include

(if cash: receipt number 5\755)

This appeal form completed

The City Clerk needs the following to process your appeal:

\$25 filing fee payable to the City of Saint Paul

Copy of the City-issued orders or letter which

radicos being appeared.	
Number & Street: 70 Wood St. City: 5	it Paul State: MV-Zip:55107
Appellant/Applicant: Torre De Son Misuel En	mil angela. dillon a common bond ong
Phone Numbers: Business 651, 224, 5839 Residence Business	1005 Cell 952.491.1960
Signature: Uni Wi	Date: 4/11/2011
Name of Owner (if other than Appellant): Common S	one Communities
Address (if not Appellant's): 58 Look St. St.	Paul, MN 55/07
Phone Numbers: Business 651.224.583 Residence	
What Is Being appealed and why?	CommonBond COMMUNITIES Torre de San Miguel www.commonbond.org
Vacate Order/Condemnation/ Revocation of Fire C of O	Angie Dillon Property Manager
Summary/Vehicle Abatement	Main 651-224-5839 Fax 651-224-9543
r Fire C of O Deficiency List	58 Wood Street, St.Paul, MN 55107
Fire C of O: Only Egress Windows	Email angela.dillon@commonbond.org
Code Enforcement Correction Notice We are requi	esting an appeal on the Key-Box
Vacant Building Registration	deficiency
Other	
o Other	- Andrews - Art - In an internal annual annu
u-Other	
TOTAL STATE OF THE PARTY OF THE	THE STATE OF THE S



CITY OF SAINT PAUL

Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220 Telephone: 651-266-8989 Saint Paul. MN 55101-1806

Fax: 651-266-8951

April 4, 2011

TORRE DE SAN MIGUEL HOMES, INC 58 WOOD ST ST. PAUL MN 55107

CORRECTION NOTICE - COMPLAINT INSPECTION

RE:

70 WOOD ST

Ref. # 78690

Dear Property Representative:

An inspection was made of your building on April 1, 2011 in response to a referral. You are hereby notified that the following deficiency list must be corrected immediately. A re-inspection will be made on April 20, 2011 after 9:30 am.

Failure to comply may result in a criminal citation or revocation of the Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

DEFICIENCY LIST

Key Box - MSFC 506.1 - Install a key box per attached K-1 handout.-Order and install key box. Provide 1. and label master keys to all entry doors and fire alarm boxes.

For an explanation or information on some of the violations contained in this report, please visit our web page at: http://www.ci.stpaul.mn.us/index.aspx?NID=211

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at: sean.westenhofer@ci.stpaul.mn.us or call me at 651-266-8982 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Sean Westenhofer Fire Inspector Ref. # 78690



328 Kellogg Blvd W St. Paul MN 55102 651-291-1750 651-291-1003 FAX www.commonbond.org

April 12, 2011

City of St. Paul 375 Jackson Street Suite 220 St. Paul, MN 55101-1806

RE: Torre De San Miguel Homes Appeal

On April 4, 2011 the property received a correction notice from the City of St. Paul on our key-box (MSFC 506.1) deficiency. The property has never been cited for an issue of not having enough key-boxes throughout the site. We currently have one key-box which is attached to the maintenance shop. This placement has worked for a number of years and there have never been any issues or concerns with it.

We would like to propose providing an additional key-box on the rental office building located in the middle of the property. This would allow for two separate locations of key-boxes on opposite sides of the property. Please consider this request.

Sincerely,

Angie Dillon

Property Manager

Torre De San Miguel Homes

951.224.5839